

**INTERNATIONAL URBAN-WILDLAND
INTERFACE CODE
HEARING RESULTS**

UWIC1-03/04

Committee Action: **Disapproved**

Committee Reason: Items 1 through 14 of the current text are activities, operations, practices or functions, not occupancies. Adding an occupancy item here would be inappropriate.

Assembly Action: **No Motion**

UWIC2-03/04

Committee Action: **Disapproved**

Committee Reason: The concept of "approved" is well-established and understood; the new terminology would cause confusion and would be inconsistent with IBC Section 106.3.1. The change would have no impact on the level of responsibility of the code official.

Assembly Action: **No Motion**

UWIC3-03/04

Committee Action: **Disapproved**

Committee Reason: The proposed text would create conflict with IBC Section 110.3 and IRC Section R110.4. Once a building is occupied, there would be no leverage in case of non-compliance.

Assembly Action: **No Motion**

UWIC4-03/04

Committee Action: **Disapproved**

Committee Reason: The hazard of materials is adequately addressed in the first paragraph of each section, therefore the new text is not needed in these sections.

Assembly Action: **No Motion**

UWIC5-03/04

Committee Action: **Disapproved**

Committee Reason: The proposal would be unenforceable. There is currently no test standard for fire resistive sealants for this application and no performance measurements. The flexibility mentioned in the reason statement is already provided by the alternative methods provisions of Chapter 1. There were no statistics provided to support the change.

Assembly Action: **No Motion**

UWIC6-03/04

Committee Action: **Disapproved**

Committee Reason: The proposal contains no guidance for designers as to how to design vents for flame or ember penetration resistance and no guidance for the code official on how to evaluate and approve such designs. It is also not clear how both ventilation and ember penetration would be achieved in the same assembly.

Assembly Action: **No Motion**

UWIC7-03/04

Committee Action: **Approved as Submitted**

Committee Reason: Based on the proponent's published reason statement.

Assembly Action: **No Motion**
