

**2007-2008 ICC CODE DEVELOPMENT CYCLE
ERRATA TO THE 2008
REPORT OF THE PUBLIC HEARING**

May 20, 2008

UPDATED July 10, 2008

IBC FIRE SAFETY

FS175-07/08, Part II – IRC B/E – Revise Section R703.9.2.2 to read as shown:

R703.9.2.2 Installation. The water resistive barrier shall be applied between the EIFS and the wall sheathing ~~over all building components.~~

(Portions of proposal not shown remain unchanged)

IBC MEANS OF EGRESS

E37-07/08 (AM) – Revise last sentence to read as shown:

1008.1.1 (IFC [B] 1008.1.1) Size of doors. The minimum width of each door opening shall be sufficient for the occupant load thereof and shall provide a minimum clear width of 32 inches (813 mm). Clear openings of doorways with swinging doors shall be measured between the face of the door and the stop, with the door open 90 degrees (1.57 rad). Where this section requires a minimum clear width of 32 inches (813 mm) and a door opening includes two door leaves without a mullion, one leaf shall provide a clear opening width of 32 inches (813 mm). The maximum width of a swinging door leaf shall be 48 inches (1219 mm) nominal. Means of egress doors in a Group I-2 occupancy used for the movement of beds shall provide a clear width not less than 41.5 inches (1054 mm). The minimum clear height of door openings shall not be less than 80 inches (2032 mm).

(Portions of proposal not shown remain unchanged)

INTERNATIONAL ENERGY CONSERVATION CODE

EC69-07/08, Part I – Revise Committee Modification to read as shown:

403.2 Furnace electricity ratio. Where not prohibited by Federal law, the fossil fuel furnaces shall have a furnace electricity ratio shall not be greater than 2% and shall include a manufacturer's designation of the furnace electricity ratio.

INTERNATIONAL FIRE CODE

F136-07/08 (AM) – Replace committee reason to read as shown:

Committee Reason: The proposal was approved because the committee felt that it will provide fire protection for the more hazardous area of garages. The modification retains the exception because Group R-3 occupancies can be sprinklered with an NFPA 13D system which would not include the garages.

F246-07/08 (AM) – Revise the first sentence of the modification to read as shown:

1.4 HMMP short form. Facilities with the maximum allowable quantities or less per control area in Tables 2703.1.1(1) through 2703.1.1(4) and where the threshold planning quantities at 40 CFR Part 355, Sections 302 and 304 are not exceeded, shall be allowed to file a short-form HMMP which shall include the following components.

IRC – PLUMBING

RP8-07/08 (AS/DF) – Replace committee reason to read as shown:

Committee Reason: The committee prefers that methods for residential sprinklers be in the Appendix of the code and not in the mandatory part of the code.
