

**Errata to the Public Comments Agenda for the
IS-HRC First Public Comments Draft Dated November 2006
(Posted January 23, 2007)**

Replace Item Ehrlich 07-Table 305A with the following:

Item: Ehrlich 07-Table 305A

5) Revision to: Section _____ Table 305A Figure _____

6) **COMMENT** Revise as follows (check BOX and state proposed change):

Revise as follows: Add new text as follows Delete and substitute as follows: Delete without Substitution:

Show the proposed NEW or REVISED or DELETED TEXT in legislative format: ~~Line through text to be deleted.~~ Underline text to be added.

**TABLE 305A
MINIMUM FOUNDATION DIMENSIONS**

Figure	Foundation Type	Minimum T (inches)	Minimum W (inches)
305B, C, D	Stem wall	10	20
305E	Solid or hollow masonry <u>stem</u> wall ¹	20	12
305F	Monolithic exterior slab on grade footing	20	12
305G	Monolithic interior slab on grade footing	20	12
305H	Stem wall with slab on grade	10	20

¹ Permitted only for basic wind speeds of 100 and 110 mph and one- and two-story structures.

COMMENT Continued (Attach additional sheets as necessary)

7) **SUPPORTING INFORMATION** (State purpose and reason, and provide substantiation to support proposed change):

The foundation wall type in Table 305A corresponding to Figure 305E is revised to indicate a masonry stem wall. The terminology is then consistent with Figure 305E and Section 305.2.2.2.