

**CHAPTER 6
FENESTRATION**

602.1.2 Performance Requirements for Windows, Sliding Glass Doors, and Glass Patio Doors: Windows, sliding glass doors, and glass patio doors shall be tested by an approved testing laboratory and bear the permanent label of an approved inspection agency to indicate compliance with the requirements of at least one of the following standards:

- a) ANSI/AAMA/NWDA 101/IS.2
- b) ANSI/AAMA/WDMA 101/IS.2/NAFS
- c) AAMA/WDMA/CSA 101/IS.2/A440

For this section and Sections 603.1 and 603.2, a label shall be *permanent* if it cannot be removed and reattached without destroying the label or product.

**TABLE 602C (notes a, b, c, d, e, f)
DESIGN WIND LOADS FOR GARAGE DOORS (psf)
For a Mean Roof Height of 30 Feet**

		Basic Wind Speed (mph – 3 second gust)						
		90	100	110	120	130	140	150
Roof Angle > 10 degrees								
Effective Area:								
Width (ft)	Height (ft)							
9	7	12.8 -14.5	15.6 -17.9	19.1 -21.6	22.6 -25.8	26.7 -30.2	31.0 -35.1	35.6 -40.2
16	7	12.3 -13.7	15.2 -16.9	18.3 -20.4	21.8 -24.3	25.6 -28.5	29.7 -33.1	34.1 -38.0

For SI: 1 foot = 304.8 mm, 1 square foot = 0.0929 sq m, 1 mile per hour = 1,609 km/h.

- a. For effective areas or wind speeds between those given above the load may be interpolated, otherwise use the load associated with the lower effective area.
- b. For mean roof heights greater than 30 feet pressures shall be multiplied by the adjustment factor of Table 602B.
- c. Pressures shall be applied in accordance with Figure 602.
- d. Plus and minus signs signify pressures acting toward and away from the building surfaces.
- e. Negative pressures assume door has 2 feet of width in building's end zone.
- f. Garage doors with effective areas greater than 16' x 7' shall be permitted to use the design wind load for the 16' x 7' door.

~~Waterproofing, sealing and flashing are important considerations in the development of hurricane resistant residential construction. Experience in 2004 with homes built to the level of structural design associated with this standard demonstrated that the homes performed very well structurally. However, there were significant problems with damage of roof coverings and soffit materials and with water intrusion into the home. The establishment of drainage planes that direct water away from the interior of the home is critical to the mitigation of water intrusion, damage to interior walls and ceilings and preventing mold growth. A study that highlights water intrusion issues and suggests potential solutions for new construction was conducted by Building Science Corporation for the Florida Home Builders Association. That report is available at: www.fhba.com/docs/Florida_Report_opt.pdf~~

TABLE 602A ^{a, b}
DESIGN WIND LOADS FOR WINDOWS AND DOORS (psf)
For A Mean Roof Height of 30 feet

	ZONE	EFFECTIVE WIND SPEED Area ^c (Feet ²)	BASIC DESIGN WIND SPEED V (mph – 3 second gust)															
			85		90		100		110		120		130		140		150	
Roof 0 to 7 degrees	1	10	5.3	-13.0	5.9	-14.6	7.3	-18.0	8.9	-21.8	10.5	-25.9	12.4	-30.4	14.3	-35.3	16.5	-40.5
	1	20	5.0	-12.7	5.6	-14.2	6.9	-17.5	8.3	-21.2	9.9	-25.2	11.6	-29.6	13.4	-34.4	15.4	-39.4
	1	50	4.5	-12.2	5.1	-13.7	6.3	-16.9	7.6	-20.5	9.0	-24.4	10.6	-28.6	12.3	-33.2	14.1	-38.1
	1	100	4.2	-11.9	4.7	-13.3	5.8	-16.5	7.0	-19.9	8.3	-23.7	9.8	-27.8	11.4	-32.3	13.0	-37.0
	2	10	5.3	-21.8	5.9	-24.4	7.3	-30.2	8.9	-36.5	10.5	-43.5	12.4	-51.0	14.3	-59.2	16.5	-67.9
	2	20	5.0	-19.5	5.6	-21.8	6.9	-27.0	8.3	-32.6	9.9	-38.8	11.6	-45.6	13.4	-52.9	15.4	-60.7
	2	50	4.5	-16.4	5.1	-18.4	6.3	-22.7	7.6	-27.5	9.0	-32.7	10.6	-38.4	12.3	-44.5	14.1	-51.1
	2	100	4.2	-14.1	4.7	-15.8	5.8	-19.5	7.0	-23.6	8.3	-28.1	9.8	-33.0	11.4	-38.2	13.0	-43.9
	3	10	5.3	-32.8	5.9	-36.8	7.3	-45.4	8.9	-55.0	10.5	-65.4	12.4	-76.8	14.3	-89.0	16.5	-102.2
	3	20	5.0	-27.2	5.6	-30.5	6.9	-37.6	8.3	-45.5	9.9	-54.2	11.6	-63.6	13.4	-73.8	15.4	-84.7
	3	50	4.5	-19.7	5.1	-22.1	6.3	-27.3	7.6	-33.1	9.0	-39.3	10.6	-46.2	12.3	-53.5	14.1	-61.5
	3	100	4.2	-14.1	4.7	-15.8	5.8	-19.5	7.0	-23.6	8.3	-28.1	9.8	-33.0	11.4	-38.2	13.0	-43.9
Roof > 7 to 27 degrees	1	10	7.5	-11.9	8.4	-13.3	10.4	-16.5	12.5	-19.9	14.9	-23.7	17.5	-27.8	20.3	-32.3	23.3	-37.0
	1	20	6.8	-11.6	7.7	-13.0	9.4	-16.0	11.4	-19.4	13.6	-23.0	16.0	-27.0	18.5	-31.4	21.3	-36.0
	1	50	6.0	-11.1	6.7	-12.5	8.2	-15.4	10.0	-18.6	11.9	-22.2	13.9	-26.0	16.1	-30.2	18.5	-34.6
	1	100	5.3	-10.8	5.9	-12.1	7.3	-14.9	8.9	-18.1	10.5	-21.5	12.4	-25.2	14.3	-29.3	16.5	-33.6
	2	10	7.5	-20.7	8.4	-23.2	10.4	-28.7	12.5	-34.7	14.9	-41.3	17.5	-48.4	20.3	-56.2	23.3	-64.5
	2	20	6.8	-19.0	7.7	-21.4	9.4	-26.4	11.4	-31.9	13.6	-38.0	16.0	-44.6	18.5	-51.7	21.3	-59.3
	2	50	6.0	-16.9	6.7	-18.9	8.2	-23.3	10.0	-28.2	11.9	-33.6	13.9	-39.4	16.1	-45.7	18.5	-52.5
	2	100	5.3	-15.2	5.9	-17.0	7.3	-21.0	8.9	-25.5	10.5	-30.3	12.4	-35.6	14.3	-41.2	16.5	-47.3
	3	10	7.5	-30.6	8.4	-34.3	10.4	-42.4	12.5	-51.3	14.9	-61.0	17.5	-71.6	20.3	-83.1	23.3	-95.4
	3	20	6.8	-28.6	7.7	-32.1	9.4	-39.6	11.4	-47.9	13.6	-57.1	16.0	-67.0	18.5	-77.7	21.3	-89.2
	3	50	6.0	-26.0	6.7	-29.1	8.2	-36.0	10.0	-43.5	11.9	-51.8	13.9	-60.8	16.1	-70.5	18.5	-81.0
	3	100	5.3	-24.0	5.9	-26.9	7.3	-33.2	8.9	-40.2	10.5	-47.9	12.4	-56.2	14.3	-65.1	16.5	-74.8
Roof > 27 to 45 degrees	1	10	11.9	-13.0	13.3	-14.6	16.5	-18.0	19.9	-21.8	23.7	-25.9	27.8	-30.4	32.3	-35.3	37.0	-40.5
	1	20	11.6	-12.3	13.0	-13.8	16.0	-17.1	19.4	-20.7	23.0	-24.6	27.0	-28.9	31.4	-33.5	36.0	-38.4
	1	50	11.1	-11.5	12.5	-12.8	15.4	-15.9	18.6	-19.2	22.2	-22.8	26.0	-26.8	30.2	-31.1	34.6	-35.7
	1	100	10.8	-10.8	12.1	-12.1	14.9	-14.9	18.1	-18.1	21.5	-21.5	25.2	-25.2	29.3	-29.3	33.6	-33.6
	2	100	11.9	-15.2	13.3	-17.0	16.5	-21.0	19.9	-25.5	23.7	-30.3	27.8	-35.6	32.3	-41.2	37.0	-47.3
	2	20	11.6	-14.5	13.0	-16.3	16.0	-20.1	19.4	-24.3	23.0	-29.0	27.0	-34.0	31.4	-39.4	36.0	-45.3
	2	50	11.1	-13.7	12.5	-15.3	15.4	-18.9	18.6	-22.9	22.2	-27.2	26.0	-32.0	30.2	-37.1	34.6	-42.5
	2	100	10.8	-13.0	12.1	-14.6	14.9	-18.0	18.1	-21.8	21.5	-25.9	25.2	-30.4	29.3	-35.3	33.6	-40.5
	3	10	11.9	-15.2	13.3	-17.0	16.5	-21.0	19.9	-25.5	23.7	-30.3	27.8	-35.6	32.3	-41.2	37.0	-47.3
	3	20	11.6	-14.5	13.0	-16.3	16.0	-20.1	19.4	-24.3	23.0	-29.0	27.0	-34.0	31.4	-39.4	36.0	-45.3
	3	50	11.1	-13.7	12.5	-15.3	15.4	-18.9	18.6	-22.9	22.2	-27.2	26.0	-32.0	30.2	-37.1	34.6	-42.5
	3	100	10.8	-13.0	12.1	-14.6	14.9	-18.0	18.1	-21.8	21.5	-25.9	25.2	-30.4	29.3	-35.3	33.6	-40.5
Wall	4	10	13.0	-14.1	14.6	-15.8	18.0	-19.5	21.8	-23.6	25.9	-28.1	30.4	-33.0	35.3	-38.2	40.5	-43.9
	4	20	12.4	-13.5	13.9	-15.1	17.2	-18.7	20.8	-22.6	24.7	-26.9	29.0	-31.6	33.7	-36.7	38.7	-42.1
	4	50	11.6	-12.7	13.0	-14.3	16.1	-17.6	19.5	-21.3	23.2	-25.4	27.2	-29.8	31.6	-34.6	36.2	-39.7
	4	100	11.1	-12.2	12.4	-13.6	15.3	-16.8	18.5	-20.4	22.0	-24.2	25.9	-28.4	30.0	-33.0	34.4	-37.8
	4	500	9.7	-10.8	10.9	-12.1	13.4	-14.9	16.2	-18.1	19.3	-21.5	22.7	-25.2	26.3	-29.3	30.2	-33.6
	5	10	13.0	-17.4	14.6	-19.5	18.0	-24.1	21.8	-29.1	25.9	-34.7	30.4	-40.7	35.3	-47.2	40.5	-54.2
	5	20	12.4	-16.2	13.9	-18.2	17.2	-22.5	20.8	-27.2	24.7	-32.4	29.0	-38.0	33.7	-44.0	38.7	-50.5
	5	50	11.6	-14.7	13.0	-16.5	16.1	-20.3	19.5	-24.6	23.2	-29.3	27.2	-34.3	31.6	-39.8	36.2	-45.7
	5	100	11.1	-13.5	12.4	-15.1	15.3	-18.7	18.5	-22.6	22.0	-26.9	25.9	-31.6	30.0	-36.7	34.4	-42.1
	5	500	9.7	-10.8	10.9	-12.1	13.4	-14.9	16.2	-18.1	19.3	-21.5	22.7	-25.2	26.3	-29.3	30.2	-33.6

For SI: 1 foot = 304.8 mm, 1 degree = 0.0174 rad, 1 mile per hour = 0.44 m/s, 1 pound per square foot = 47.9N/m².

a. For mean roof heights greater than 30 feet, pressures shall be multiplied by the adjustment factor of Table 602B.

b. Pressures shall be applied in accordance with Figure 602.

c. The effective wind area is the span length multiplied by an effective width that need not be less than one-third the span length. For cladding fasteners, the effective wind area shall not be greater than the area that is tributary to an individual fastener.

603 WINDBORNE DEBRIS

603.1 PROTECTION. In regions within one mile of the coastal mean high water line where the basic wind speed shown on Figure 104A is 110 mph or greater and in all regions where the basic wind speed shown is 120 mph or greater; windows, unit skylights, sliding glass doors, and glass patio doors shall be protected with tested, ~~labeled~~ permanently labeled and approved impact resistant covering in compliance to the large ~~missile~~ missile test requirement of the specifications listed in this section.

Where not protected, the window, unit skylights, sliding glass doors, and glass patio doors shall be impact resistant and tested and approved by an independent laboratory, listed by an approved entity and bear a permanent label identifying manufacturer, performance characteristics, and approved inspection agency to indicate compliance to the large missile test requirements of the following specifications:

ASTM E1886 and ASTM E 1996 or
AAMA 506

EXCEPTION: Instead of tested external protection devices, wood structural panels may be used when they cover the glazed openings with a minimum thickness of 7/16 inch, a maximum panel span of 8 feet, and provided with attachments in accordance with Table 603. Panels shall be precut to cover the glazed openings and sized appropriately for the attachment method provided. Panels shall be pre-drilled as required for the anchorage method and all required hardware shall be provided. Permanent corrosion resistant attachment hardware shall be provided in accordance with Table 603 or sized and spaced to resist the component and cladding loads in accordance with Table 602A.

603.2 WINDBORNE DEBRIS (IMPACT) COMPLIANCE FOR OTHER DOORS IN WINDBORNE DEBRIS AREAS: Doors not included in Section 603.1 shall be protected with tested, permanently labeled and approved impact resistant covering. Where not protected, doors shall be impact resistant and tested to indicate compliance to the large ~~missile~~ missile test requirements of at least one of the following standards:

ASTM E 1886 and ASTM E 1996
ANSI/DASMA 115 (for garage doors)
TAS 201, TAS 202, and TAS 203
