

# Fire Door Test Summary

This report is for the period: January 1, 1990 to December 31, 1999

12-Mar-15

<i>Door Type</i>	<i>Door Label</i>	<i>No. Tested</i>	<i>Failed</i>	<i>% Failed</i>
<i>Damper/Shutter (D)</i>	NL	249	17	6.8%
	OL	69	0	0.0%
	UL	228	8	3.5%
		<b>546</b>	<b>25</b>	<b>4.6%</b>
<i>Horizontal Sliding - Inclined Track (H1)</i>	FM	149	25	16.8%
	NL	293	41	14.0%
	OL	156	16	10.3%
	OS	23	7	30.4%
	UL	526	69	13.1%
	UO	6	1	16.7%
		<b>1153</b>	<b>159</b>	<b>13.8%</b>
<i>Horizontal Sliding - Counterweight Closure (H2)</i>	FM	874	124	14.2%
	NL	510	63	12.4%
	OL	250	29	11.6%
	OS	241	52	21.6%
	UL	1053	96	9.1%
	UO	2	2	100.0%
		<b>2930</b>	<b>366</b>	<b>12.5%</b>
<i>Horizontal Sliding - Spring Closure (H3)</i>	FM	79	21	26.6%
	NL	43	0	0.0%
	UL	133	22	16.5%
	UO	15	2	13.3%
		<b>270</b>	<b>45</b>	<b>16.7%</b>
<i>Rolling Steel Spring Operated (R1)</i>	---	1	0	0.0%
	FM	4197	620	14.8%
	FN	1	0	0.0%
	NL	1535	248	16.2%
	OL	311	69	22.2%
	OS	2079	326	15.7%
	UL	4812	671	13.9%
	UO	382	56	14.7%
		<b>13318</b>	<b>1990</b>	<b>14.9%</b>

<i>Door Type</i>	<i>Door Label</i>	<i>No. Tested</i>	<i>Failed</i>	<i>% Failed</i>
<i>Rolling Steel Non-Spring Operated (R2)</i>	FM	4	0	0.0%
	OS	35	2	5.7%
		<b>39</b>	<b>2</b>	<b>5.1%</b>
<i>Rolling Steel Non-Spring Operated Retrofit (R3)</i>	FM	124	31	25.0%
	NL	5	0	0.0%
	OS	32	1	3.1%
	UO	12	1	8.3%
		<b>173</b>	<b>33</b>	<b>19.1%</b>
<i>Swinging (S)</i>	FM	2661	185	7.0%
	NL	1241	107	8.6%
	OL	687	51	7.4%
	OS	1	0	0.0%
	UL	3996	301	7.5%
		<b>8586</b>	<b>644</b>	<b>7.5%</b>
<i>Vertical Sliding (VI)</i>	---	1	1	100.0%
	FM	50	6	12.0%
	NL	362	47	13.0%
	OL	37	12	32.4%
	UL	178	24	13.5%
		<b>628</b>	<b>90</b>	<b>14.3%</b>
<b>Grand Total:</b>		<b>27643</b>	<b>3354</b>	<b>12.1%</b>