

# GEW164-14

## 703.7.3, 703.8

**Proponent:** Dru Meadows, The Green Team, Inc., representing Walmart  
(dmeadows@thegreenteaminc.com)

**Delete without substitution:**

~~**703.7.3 Metering.** The metering of mechanical systems, system components, equipment and appliances shall be conducted in accordance with Section 705.1.~~

**Revise as follows:**

**703.8 Wet-hood exhaust scrubber systems.** Where wet-hood exhaust scrubber systems are used, they shall incorporate a water recirculation system. ~~The makeup water supplies for such systems shall be metered in accordance with Section 705.1.~~

**Reason:** Metering requirements are in Section 705 (Metering). The language in 703.7.3 and 703.8 does not add any further requirements. There are no similar cross references for other systems or equipment (e.g. irrigation or nonpotable systems).  
Removing the cross references will simplify the code language without diminishing the requirements or application.

**Cost Impact:** Will not increase the cost of construction.

GEW164-14: 703.7.3-MEADOWS683

---