

GEW17-14

602.1.2

Proponent: David Collins, The Preview Group, Inc., representing American Institute of Architects (dcollins@preview-group.com)

Revise as follows:

602.1.2 Base annual Annual energy use index indices. The proposed energy use index (EUIp) and the base energy use index (EUI) of the building and building site shall be calculated in accordance with ~~Equation 6-1 and~~ Appendix G to ASHRAE 90.1, as modified by Sections 602.1.2.1 through ~~602.1.2.3~~ 602.1.2.2. The annual energy use shall include all energy used for building and building site functions and ~~its~~ anticipated occupancy.

Reason: This proposal seeks to clarify that this Section directs the user to perform modeling for both the proposed and base project designs using the Appendix G of ASHRAE 90.1, as modified

Cost Impact: Will not increase the cost of construction.

GEW17-14: 602.1.2-COLLINS693
