

GEW7-14

601.3, 601.3.1, 601.3.2, 601.4

Proponent: Jack Bailey, One Lux Studio, representing self (jbailey@oneluxstudio.com)

Revise as follows:

601.3 Application. Buildings and their associated building sites shall comply with Section 601.3.1 or Section 601.3.2.

601.3.1 Performance-based compliance. Buildings designed on a performance basis shall comply with Sections 602, 608.6, 609, and 610 ~~and 611~~.

601.3.2 Prescriptive-based compliance. Buildings designed on a prescriptive basis shall comply with the requirements of Sections 605, 606, 607, 608, 609, and 610 ~~and 611~~.

601.4 Minimum requirements. Buildings shall be provided with metering complying with Section 603, and commissioning complying with Section 611. Where required in accordance with Section 604.1, building shall be provided with automated-demand response complying with Section 604.

Reason: There is no reason to list Section 611 in 601.3.1 and 601.3.2 when it is already listed as a minimum requirement in 601.4, and other "minimum requirements" in 601.4 are not listed in 601.3.1 and 601.3.2.

Cost Impact: Will not increase the cost of construction.

GEW7-14: 601.3.1-BAILEY587
