

GG286-14

1001.4

Proponent: Richard Miller, International Association of Fire Chiefs, representing FLSS IAFC (rmiller@iafc.org)

Revise as follows:

1001.4 Existing materials, assemblies, configurations and systems. Materials, assemblies, configurations and systems already in use that conform to requirements or approvals in effect at the time of their erection or installation shall be permitted to remain in use ~~unless determined by the code official to be dangerous to life, health or safety. Where such conditions are determined to be dangerous to the environment, life, health or safety, they shall be mitigated or made safe.~~

Reason: This existing language sets up a direct conflict with the scope, intent and applicability of the IFC due to a lack of determination, clarity or guidance on the code official's perspective of what may constitute a danger to life, safety or health.
"This proposal is approved by the Fire-CAC, but not reviewed by the SEHP-CAC"

Cost Impact: Will not increase the cost of construction.

GG286-14 : 1001.4-MILLER446