

2006 International Mechanical Code Errata

THIRD PRINTING (UPDATED May, 2008)

CHAPTER 4

Section 401.4.3 Flood Hazard.

For structures located in flood hazard areas, outdoor exhaust and air intake openings shall be at or above the design flood elevation.

2006 International Mechanical Code Errata

FIRST PRINTING (UPDATED May, 2008)

CHAPTER 4

Table 403.3 Required outdoor ventilation air.

Public spaces

Smoking lounges ^{b,h,g}