

2006 International Mechanical Code Errata

FIRST PRINTING (UPDATED May, 2008)

CHAPTER 5

501.2.1 Location of exhaust outlets.

Item 4. For specific systems: For clothes dryer exhaust, see Section 504.4; for kitchen hoods, see Section 506.3; for dust, stock and conveying systems, see Section 511.2; and for subslab soil exhaust systems, see Section 512.4.

506.3.3.1 Grease duct test is renumbered as **Section 506.3.2.5.**

506.3.3 Grease duct supports.

Delete last paragraph as follows:

~~A test shall be performed for the entire duct system including the hood to duct transition connection. The ductwork shall be permitted to be tested in sections, provided that every joint is tested.~~