

**2000 INTERNATIONAL ENERGY  
CONSERVATION CODE ERRATA  
8<sup>TH</sup> PRINTING (Updated April 22, 2011)**

---

**2000 IECC  
CHAPTER 8  
DESIGN BY ACCEPTABLE PRACTICE FOR COMMERCIAL BUILDINGS**

**803.3.6 Duct and plenum insulation and sealing.** All ducts and plenums shall be insulated and sealed in accordance with Section 803.2.8.

Ducts designed to operate at static pressures in excess of 3 inch water gauge (wg)(746 Pa) shall be leak-tested in accordance with the SMACNA *HVAC Air Duct Leakage Test Manual* with the rate of air leakage (CL) less than or equal to 6.0 as determined in accordance with Equation 8-2.

$$\cancel{CL = F \times P^{0.65}} \quad CL = F / P^{0.65}$$

(Equation 8-2)

(No change to remainder of section)