

ERRATA TO THE 2000 INTERNATIONAL ENERGY CONSERVATION CODE

Third Printing, September 2001

Updated March 29, 2002

Section 101.4 Scope.

Delete exception in its entirety.

Second Printing, January 2001

(See also Third Printing, September 2001)

Table 502.2.1.1.2(1) Required U_w for Wall with a Heat Capacity Equal to or Exceeding 6 Btu/ft². °F with Insulation Placed on the Exterior of the Wall Mass

Under column 0.08, the 0.19 should be 0.09.

Under column 0.24, the 030 should be 0.30.

Table 502.2.1.1.2(2) Required U_w for Wall with a Heat Capacity Equal to or Exceeding 6 Btu/ft². °F with Insulation Placed on the Exterior of the Wall Mass

Under the column 0.08, the 0.9 should be 0.09.

First Printing, December 1999

(See also Second Printing, January 2001)

Section 202 GENERAL DEFINITIONS

Under definition **COMFORT ENVELOPE**,

Revise the second line to read:

“...described in Figure 2...”

Section 402.1.3.1.4 Fenestration system solar heat gain coefficient, Standard design.

Revise the third to last line to read:

“...specified in Section 402.1.3.1.5 to arrive at an overall...”

Section 502.1.3 Recessed lighting fixtures.

Revise Item 3 first sentence to read:

3. Type IC rated, in accordance with ASTM E 283 admitting no more than 2.0 cubic feet per minute (cfm) (0.944 L/s) of air movement from the conditioned space to the ceiling cavity.

Table 502.2.4.17(1) High-Mass Wall Equivalent R-Values Insulation Placed on the Exterior of the Wall or with Integral Insulation.

Revise Row R-22 under HDD 5,500-6,499 column to read R-12.

Table 503.2 Minimum Equipment Performance.

Revise footnote d to read:

- d. Except for gas-fired steam boilers for which the minimum AFUE shall be 75 percent.

Table 503.3.3.3

Under heading "HEATING", column for Annual cooling degree days.

Revise to read: Annual heating degree days.

Section 602.4 Replacement fenestration.

Revise the fourth line as follows:

"...*U*-factor that does not exceed the "Fenestration *U*-factor" requirement in Table 502.2.5 applicable to the climate zone..."

Table 802.2(11) Building Envelope Requirements - Climate Zone 3c.

For the category "Window and Glazed Door Area Over 25 Percent But Not Greater Than 40 Percent of Above-grade Wall Area", under the "Metal framing" column, revise the criteria for "other masonry walls, R-value continuous" from "R-11" to "R-0".

Table 802.2(16) Building Envelope Requirements - Climate Zone 6a.

For the category "Window and Glazed Door Area Over 40 Percent But Not Greater Than 50 Percent of Above-grade Wall Area", under the "Roof assemblies", "Continuous insulation" column, revise the criteria for "Metal purlin without thermal block" from "R-30" to "R-20".

Table 802.2(31) Building Envelope Requirements - Climate Zone 14a.

For the category "Window and Glazed Door Area Over 40 Percent But Not Greater Than 50 Percent of Above-grade Wall Area", under the "Metal framing" column, revise the criteria for "other masonry walls, R-value cavity" from "R-11" to "R-11".

Section 803.2.2 HVAC equipment performance requirements.

Revise second line to read:

"...of Tables 803.2.2(1), 803.2.2(2), 803.2.2(3), 803.2.2(4) and 803.2.2(5),..."

Chapter 9 AAMA Standards.

Revise AAMA's address to read:

American Architectural Manufacturers Association
1827 Walden Office Square
Suite 104
Schaumburg, IL 60173-4628

Chapter 9 ASHRAE Standards.

Delete both ASHRAE—75.

Chapter 9 ASME Standards.

Revise ASME's address to read:

"...Three Park Avenue New York, NY 10016-5990"

Chapter 9 IES Standards.

Change the designation of IES to read:

"IESNA"