

This Appendix (2000 IRC Appendix-L) is produced, copyrighted, and maintained by the National Fire Protection Association

Association, all rights reserved. Use of this Appendix is pursuant to license with the NFPA.

The title National Electrical Code and the acronym NEC are registered trademarks of the National Fire Protection Association, Quincy, Massachusetts.

APPENDIX - L

INTERNATIONAL RESIDENTIAL CODE ELECTRICAL

This table is a cross reference of the *International Residential Code*, Chapters 33 through 42, and the 1999 *National Electrical Code* (NFPA 70-1999).

IRC Section	Section Title	NEC Section
CHAPTER 33 GENERAL REQUIREMENTS		
E3301 GENERAL		
E3301.1	Applicability	None
E3301.2	Scope	90-1 and 90-2
E3301.3	Not covered	90-2
E3301.4	Additions and alterations	None
E3302 BUILDING STRUCTURE PROTECTION		
E3302.1	Drilling and notching	None
E3302.2	Penetrations of fire-resistance-rated assemblies	Section 300-21
E3302.3	Penetrations of firestops and draftstops	300-21
E3303 INSPECTION AND APPROVAL		
E3303.1	Approval	110-2
E3303.2	Inspection required	None
E3303.3	Listing and labeling	110-3
E3304 GENERAL EQUIPMENT REQUIREMENTS		
E3304.1	Voltages	110-4
E3304.2	Interrupting rating	110-9
E3304.3	Circuit characteristics	110-10
E3304.4	Protection of equipment	110-11
E3304.5	Unused openings	110-12(a)
E3304.6	Integrity of electrical equipment	110-12(c)
E3304.7	Mounting	110-13(a)
E3304.8	Energized parts guarded against accidental contact	110-27(a)
E3304.9	Prevent physical damage	110-27(b)
E3304.10	Equipment identification	110-21
E3304.11	Identification of disconnecting means	110-22

IRC Section	Section Title	NEC Section
E3305	EQUIPMENT LOCATION AND CLEARANCES	
E3305.1	Working space and clearances	110-26
Figure E3305.1	Working space and clearances	110-26
	Footnote a.	110-26(f)
	Footnote b.	110-26(e)
	Footnote c.	110-26(b)
	Footnote d.	230-70(a), 240-24(d) and 240-24(e)
	Footnote e.	110-26(d)
E3305.2	Working clearances for energized equipment and panelboards	110-26(a), 110-26(d), and 110-26(f)
E3305.3	Clearances over panelboards	110-26(f)(1)(a)
E3305.4	Location of clear spaces	110-26(b), 230-70(a) and 240-24
E3305.5	Access and entrance to working space	110-26(c)
E3305.6	Illumination	110-26(d)
E3305.7	Headroom	110-26(e)
E3306	ELECTRICAL CONDUCTORS AND CONNECTIONS	
E3306	General	Article 110, and § 310-1
E3306.2	Conductor material	110-5
E3306.3	Minimum size of conductors	310-5
E3306.4	Stranded conductors	310-3
E3306.5	Individual conductor insulation	310-2(a)
E3306.6	Conductors in parallel	310-4
E3306.7	Conductors of the same circuit	300-3(b)
E3306.8	Aluminum and copper connections	110-14
E3306.9	Terminals	110-14(a)
E3306.10	Splices	110-14(b)
E3306.10.1	Continuity	300-13(a)
	Exception	300-13(a)
E3306.10.2	Device connections	250-148 and 300-13(b)
E3306.10.3	Length of conductor for splice or termination	300-14
E3307	CONDUCTOR AND TERMINAL IDENTIFICATION	
E3307.1	Grounded conductors	200-6(a), 200-6(b) and 310-12(a)
E3307.2	Equipment grounding conductors	250-119 and 310-12(b)
E3307.3	Ungrounded conductors	310-12(c)
	Exception	200-7(c)(2)
E3307.4	Identification of terminals	200-10
E3307.4.1	Device terminals	200-10(a)
E3307.4.2	Receptacles, plugs, and connectors	200-10(b)
E3307.5	Tag marking	310-11(b)(3)

IRC Section	Section Title	NEC Section
CHAPTER 34	<u>ELECTRICAL DEFINITIONS</u>	
E3401	GENERAL	Article 100, Definitions
	Arc-fault circuit-interrupter	210-12(a)
CHAPTER 35	<u>SERVICES</u>	
3501	GENERAL SERVICES	
E3501.1	Scope	230-1
E3501.2	Number of services	230-2
E3501.3	One building or other structure not to be supplied through another	230-3
E3501.4	Other conductors in raceway or cable	230-7
E3501.5	Raceway seal	230-8
E3501.6	Service disconnect required	230-70
E3501.6.1	Marking of service equipment and disconnects	230-66 & 230-70(b)
E3501.6.2	Service disconnect location	230-70(a) & 230-72(c)
E3501.7	Maximum number of disconnects	230-71(a)
E3502	SERVICE SIZE AND RATING	
E3502.1	Rating of ungrounded conductors	230-79(c) and (d)
E3502.2	Service load	220-30
Table E3502.2	Minimum service load calculation	Table 220-30
E3502.2.1	Services under 100 amperes	None
E3502.3	Rating of service disconnect	230-79
E3502.4	Voltage rating	220-30(a)
E3503	SERVICE, FEEDER AND GROUNDING ELECTRODE CONDUCTOR SIZING	
E3503.1	Grounded and ungrounded service conductor size	310-15(b)(6)
Table E3503.1	Service conductor and grounding electrode conductor sizing	Table 310-16 and Table 250-66
	Footnote a.	250-64(e)
	Footnotes b. and c.	250-64(b)
	Footnote d.	250-66(a) and (b)
E3503.2	Ungrounded service conductors for accessory buildings and structures	230-42(b)
	Exceptions 1,2, and 3	230-42(b) and 230-79
E3503.3	Overload protection	230-90
E3503.3.1	Ungrounded conductor	230-90(a)
	Exception	230-90(a), Exception No. 3
E3503.3.2	Not in grounded conductor	230-90(b)
E3503.4	Grounding electrode conductor size	250-66

IRC Section	Section Title	NEC Section
E3504	OVERHEAD SERVICE-DROP AND SERVICE CONDUCTOR INSTALLATION	
E3504.1	Clearance from building openings	230-9
Figure E3504.1	Clearances from building openings	230-9
E3504.2	Vertical clearances	230-24
E3504.2.1	Above roofs	230-24(a)
	Exception 1	230-24(a), Exception No. 1
	Exception 2	230-24(a), Exception No. 2
	Exception 3	230-24(a), Exception No. 3
	Exception 4	230-24(a), Exception No. 4
Figure E3504.2.1	Clearances from roofs	230-24
E3504.2.2	Vertical clearance from grade	230-24(b)
	Items 1, 2, and 3	230-24(b)
E3504.3	Point of attachment	230-26
E3504.4	Means of attachment	230-27
E3504.5	Service masts as supports	230-28
E3504.6	Supports over buildings	230-29
E3505	SERVICE-ENTRANCE CONDUCTORS	
E3505.1	Insulation of service-entrance conductors	230-41
	Exceptions 1 and 2	230-41, Exception
E3505.2	Wiring methods for services	230-43
E3505.3	Spliced conductors	230-46
E3505.4	Protection against physical damage	230-49
E3505.5	Protection of service cables against damage	230-50(a)
E3505.6	Mounting supports	230-51
E3505.7	Raceways to drain	230-53
E3505.8	Overhead service locations	230-54
E3505.8.1	Raintight service head	230-54(a)
E3505.8.2	Service cable, service head or gooseneck	230-54(b)
E3505.8.3	Service head location	230-54(c)
	Exception	230-54(c), Exception
E3505.8.4	Separately bushed openings	230-54(e)
E3505.8.5	Drip loops	230-54(f)
E3505.8.6	Conductor arrangement	230-54(g)
E3505.8.7	Secured	230-54(d)
E3505.9	Termination at service equipment	230-55
E3506	SERVICE EQUIPMENT—GENERAL	
E3506.1	Service equipment enclosures	230-62
E3506.2	Working space	110-26
E3506.3	Available short-circuit current	None
E3506.4	Marking	230-66

IRC Section	Section Title	NEC Section
E3507	SYSTEM GROUNDING	
E3507.1	System service ground	250-20(b)(1) and 250-24(a)
E3507.2	Location of grounding electrode conductor connection	250-24(a)(1) and (a)(5)
E3507.3	Two or more buildings or structures supplied from a common service	250-32(a)
	Exception	250-32(a), Exception
E3507.3.1	Equipment grounding conductor	250-32(b)(1) and Table 250-122
E3507.3.2	Grounded conductor.	250-32(b)(2)
E3507.4	Grounding electrode conductor	250-24(c)
E3507.5	Main bonding jumper	250-28
E3507.6	Common grounding electrode	250-58
E3508	GROUNDING ELECTRODE SYSTEM	
E3508.1	Grounding electrode system	250-50
E3508.1.1	Metal underground water pipe	250-50(a)
E3508.1.2	Concrete-encased electrode	250-50(c)
E3508.2	Made and other electrodes	250-52
E3508.2.1	Rod and pipe electrodes	250-52(c)(1) and (2)
E3508.2.2	Installation	250-52(c)(2)
E3508.2.3	Aluminum electrodes	Section 250-52(e)
E3508.3	Resistance of made electrodes	250-56
E3508.4	Metal underground gas piping system	250-104(b)
E3509	BONDING	
E3509.1	General	250-90
E3509.2	Bonding of service equipment	250-92(a)
E3509.3	Bonding to other systems	250-92(b)
E3509.4	Method of bonding at the service	250-94
E3509.4.1	Grounded service conductor	250-94(1)
E3509.4.2	Threaded connections	250-94(2)
E3509.4.3	Threadless couplings and connectors	250-94(3)
E3509.4.4	Other devices	250-94(4)
E3509.5	Sizing bonding jumper on supply side of service and main bonding jumper	250-102(c)
E3509.6	Metal water piping bonding	250 250-104(a)
E3509.7	Metal gas piping bonding	250 250-104(b)
E3509.8	Bonding other metal piping	250-104(c)
E3510	GROUNDING ELECTRODE CONDUCTORS	
E3510.1	Installation	250-64(a) and (b)
E3510.2	Enclosures for grounding electrode conductors	250-64(e)

IRC Section	Section Title	NEC Section
E3511	GROUNDING ELECTRODE CONDUCTOR CONNECTION TO GROUNDING ELECTRODES	
E3511.1	Methods of grounding connection to electrodes	Section 250-70
E3511.2	Accessibility	Section 250-68
E3511.3	Effective grounding path	Section 250-68
E3511.4	Protection of ground clamps and fittings	Section 250-10
E3511.5	Clean surfaces	Section 250-12

CHAPTER 36 **BRANCH CIRCUIT AND FEEDER REQUIREMENTS**

E3601 **GENERAL**

E3601.1	Scope	None
E3601.2	Branch-circuit and feeder ampacity	Sections 210-19(a) and 215-2
E3601.3	Multioutlet branch circuits	210-19(b)
E3601.4	Multiwire branch circuits	Section 210-4

E3602 **BRANCH CIRCUIT RATINGS**

E3602.1	Branch-circuit voltage limitations	Sections 210-6(a) and (b)
E3602.2	Branch-circuit ampere rating	Section 210-3
E3602.3	Fifteen- and 20-ampere branch circuits	Section 210-23(a)
E3602.4	Thirty-ampere branch circuits	Section 210-23(b)
E3602.5	Branch circuits serving multiple loads or outlets	Section 210-23(a)
E3602.6	Branch circuits serving a single motor	Section 430-22(a)
E3602.7	Branch circuits serving motor-operated and combination loads	Section 220-4(a)
E3602.8	Branch-circuit inductive lighting loads	Section 210-22(b), 220-4(b)
E3602.9	Branch-circuit load for ranges and cooking appliances	Table 220-19, Note 4
E3602.9.1	Minimum branch circuit for ranges	Section 210-19(c)
E3602.10	Branch circuits serving heating loads	Sections 422-13 and 424-3(a) and (b)
E3602.11	Branch circuits for air-conditioning and heat pump equipment	Sections 440-35 and 440-52(a)(3)
E3602.12	Branch circuits serving room air conditioners	Section 440-62(a)
E3602.12.1	Where no other loads are supplied	Section 440-62(b)
E3602.12.2	Where lighting units or other appliances are also supplied	Section 440-62(c)
E3602.13	Branch-circuit requirement—summary	Section 210-24 and 210-25
Table E3602.13	Branch-circuit requirement—summary	Table 210-24

IRC Section	Section Title	NEC Section
E3603	REQUIRED BRANCH CIRCUITS	
E3603.1	Branch circuits for heating	Section 422-12
E3603.2	Kitchen and dining area receptacles	Section 210-11(c)(1)
E3603.3	Laundry circuit	Sections 210-23(a), Exception and 210-11(c)(2)
E3603.4	Bathroom Branch Circuits	Section 210-11(c)(3)
E3603.5	Number of branch circuits	Section 210-11(a)
E3603.6	Branch-circuit load proportioning	Section 210-11(b)
E3604	FEEDER REQUIREMENTS	
E3604.1	Conductor size	Table 310-15(b)(6), Sections 215-2 and 220-10(a)
E3604.2	Minimum feeder conductor size	215-2(b)
E3604.3	Feeder loads	Table 220-11
Table E3604.3(1)	Feeder load calculation	Table 220-11, Table 220-30(c), Sections 220-14, 220-15, 220-18 & 220-19
Table E3604.3(2)	Demand loads for electric ranges, wall-mounted ovens, counter-mounted cooking units and other cooking appliances over 13/4 kVA rating	Table 220-19
E3604.4	Feeder neutral load	220-22
E3604.5	Lighting and convenience receptacle load	220-3(a)
E3604.6	Ampacity and computed loads	220-10(a)
E3604.7	Feeder and branch-circuit conductors	240-21(a)
E3605	CONDUCTOR SIZING AND OVERCURRENT PROTECTION	
E3605.1	General	310-15(a)
Table E3605.1	Allowable ampacities	Table 310-16
E3605.2	Correction factors for ambient temperatures	Table 310-16
Table E3605.2	Ambient temperature correction factors	Table 310-16, Correction factors
E3605.3	Adjustment for conductor proximity	310-15(b)(2)(a)
Table E3605.3	Conductor proximity adjustment factors	Table 310-15(b)(2)(a)
E3605.4	Temperature limitations	110-14(c)
E3605.4.1	Conductors rated 60°C.	110-14(c)(1)
E3605.4.2	Conductors rated 75°C.	110-14(c)(2)
E3605.4.3	Separately installed pressure connectors	110-14(c)(3)
E3605.4.4	Conductors of type NM cable	33630(b) and 336-26
E3605.5	Overcurrent protection required	Table 310-15(b)(6), Sections 240-3 & 240-4
E3605.5.1	Cords	Section 240-4
E3605.5.2	Overcurrent devices of the next higher size	240-3(b)
E3605.5.3	Small conductors	240-3(d)
E3605.5.4	Air conditioning and heat pump equipment	240-3(g)
E3605.6	Fuses and fixed trip circuit breakers	240-6
E3605.7	Overcurrent device location	240-24(e)

IRC Section	Section Title	NEC Section
-------------	---------------	-------------

E3605 CONDUCTOR SIZING AND OVERCURRENT PROTECTION (Cont.)

E3605.8	Location of overcurrent devices in or on premises	240-24
E3605.9	Ready access for occupants	240-24(b)
E3605.10	Enclosures for overcurrent devices	240-240-30

E3606 PANELBOARDS

E3606.1	Panelboard rating	384-13
E3606.2	Panelboard circuit identification	384-13
E3606.3	Panelboard overcurrent protection	384-16(a)

CHAPTER 37 WIRING METHODS

E3701 GENERAL REQUIREMENTS

E3701.1	Scope	300-1
E3701.2	Allowable wiring methods	110-8 and 300-3
Table E3701.2	Allowable wiring methods	None
E3701.3	Circuit conductors	300-3(b)
E3701.4	Wiring method applications	Chapter 3 and Section 300-2
Table E3701.4	Allowable applications for wiring methods	Chapter 3 and Section 300-2

E3702 ABOVEGROUND INSTALLATION REQUIREMENTS

E3702.1	Installation and support requirements	Chapter 3
Table E3702.1	General installation and support requirements for wiring methods	Chapter 3
E3702.2	Cables in accessible attics	333-12 and 336-6(d)
E3702.2.1	Across structural members	333-12(a)
E3702.2.2	Cable installed parallel to framing members	333-12(b)
E3702.3	Exposed cable	333-11 and 336-6
E3702.3.1	Surface installation	336-6(a)
E3702.3.2	Protection from physical damage	336-6(b)
E3702.4	In unfinished basements	336-6(c)
E3702.5	Bends	333-8 and 336-16

E3703 UNDERGROUND INSTALLATION REQUIREMENTS

E3703.1	Minimum cover requirements	300-5(a)
Table E3703.1	Minimum cover requirements, burial in inches	Table 300-5
E3703.2	Grounding	300-5(b)
E3703.3	Protection from damage	300-5(d)
E3703.4	Splices and taps	300-5(e)
E3703.5	Backfill	300-5(f)
E3703.6	Raceway seals	300-5(g)
E3703.7	Bushing	300-5(h)
E3703.8	Single conductors	300-5(i)
E3703.9	Ground movement	300-5(j)

IRC Section	Section Title	NEC Section
-------------	---------------	-------------

CHAPTER 38 POWER AND LIGHTING DISTRIBUTION

E3801 RECEPTACLE OUTLETS

E3801.1	General	210-50 and 210-52
E3801.2	Convenience receptacle distribution	210-52(a)
E3801.2.1	Spacing	210-52(a)(1)
E3801.2.2	Wall space	210-52(a)(2)
E3801.2.3	Floor receptacles	210-52(a)(3)
E3801.3	Small appliance receptacles	210-52(b)
E3801.3..1	Rooms	210-52(b)(1)
E3801.3.2	No other outlets	210-52(b)(2)
E3801.3.3	Limitations	210-52(b)(3)
E3801.4	Countertop receptacles	210-52(c)
E3801.4.1	Wall counter space	210-52(c)(1)
E3801.4.2	Island counter spaces	210-52(c)(2)
E3801.4.3	Peninsular counter space	210-52(c)(3)
E3801.4.4	Separate spaces	210-52(c)(4)
E3801.4.5	Receptacle outlet location	210-52(c)(5)
E3801.5	Appliance outlets	210-50(c)
E3801.6	Bathroom and toilet room	210-52(d)
E3801.7	Outdoor outlets	210-52(e)
E3801.8	Laundry areas	210-52(f)
E3801.9	Basements and garages	210-52(g)
E3801.10	Hallways	210-52(h)
E3801.11	HVAC outlet	210-63

E3802 GROUND-FAULT AND ARC-FAULT CIRCUIT-INTERRUPTER PROTECTION

E3802.1	Bathroom receptacles	210-8(a)(1)
E3802.2	Garage receptacles	210-8(a)(2)
E3802.3	Outdoor receptacles	210-8(a)(3)
E3802.4	Crawl space receptacles	210-8(a)(4)
E3802.5	Unfinished basement receptacles	210-8(a)(5)
E3802.6	Kitchen receptacles	210-8(a)(6)
E3802.7	Bar sink receptacles	210-8(a)(7)
E3802.8	Exempt receptacles	210-8(a)(2)
E3802.9	Bedroom receptacles (as of 2002 IRC Supplement)	210-12(b)

E3803 LIGHTING OUTLETS

E3803.1	General	210-70(a)
E3803.2	Habitable rooms	210-70(a)(1)
E3803.3	Additional locations	210-70(a)(2)
E3803.4	Storage or equipment spaces	210-70(a)(3)

E3804 GENERAL INSTALLATION REQUIREMENTS

E3804.1	Electrical continuity of metal raceways and enclosures	300-10
E3804.2	Mechanical continuity—raceways and cables	300-12
E3804.3	Securing and supporting	300-11(a)
E3804.4	Raceways as means of support	300-11(b)
E3804.5	Raceway installations	300-18

IRC Section	Section Title	NEC Section
E3804	GENERAL INSTALLATION REQUIREMENTS	
E3804.6	Conduit and tubing fill	300-17 and Chapter 9, Table 1
Tables E3804.6(1) & E3804.6(10)	Maximum number of conductors in conduit or tubing	300-17 and Chapter 9, Table 1, Note 1
E3804.7	Air handling—stud cavity and joist spaces	300-22(c), Exception
E3805	BOXES, CONDUIT BODIES, AND FITTINGS	
E3805.1	Box, conduit body, or fitting, — where required	300-15
E3805.1.1	Equipment	300-15(b)
E3805.1.2	Protection	300-15(c)
E3805.1.3	Integral enclosure	300-15(e)
E3805.1.4	Fitting	300-15(f)
E3805.1.5	Buried conductors	300-15(g)
E3805.1.6	Fixtures	300-15(j)
E3805.1.7	Closed loop	300-15(m)
E3805.3	Metal boxes	370-4
E3805.4	Nonmetallic boxes	370-3
E3805.4.1	Nonmetallic-sheathed cable and nonmetallic boxes	370-17(c)
E3805.4.2	Securing to box	370-17(c)
E3805.4.3	Conductor rating	370-17(c)
E3805.5	Minimum depth of outlet boxes	370-24
E3805.6	Boxes enclosing flush-mounted devices	370-19
E3805.7	Boxes at lighting fixture outlets	370-27(a)
E3805.8	Floor boxes	370-27(b)
E3805.9	Boxes at fan outlets	370-27(c)
E3805.10	Conduit bodies, junction, pull and outlet boxes to be accessible	370-29
E3805.11	Damp or wet locations	370-15
E3805.12	Number of conductors in outlet, device, and junction boxes, and conduit boxes	370-16(a)
E3805.12.1	Box volume calculations	370-16(a)
Table E3805.12.1	Maximum number of conductors in metal boxes	Table 370-16(a)
E3805.12.1.1	Standard boxes	370-16(a)(1)
E3805.12.1.2	Other boxes	370-16(a)(2)
E3805.12.2	Box fill calculations	370-16(b)
E3805.12.2.1	Conductor fill	370-16(b)(1)
Table E3805.12.2.1	Volume allowance required per conductor	Table 370-16(b)
E3805.12.2.2	Clamp fill	370-16(b)(2)
E3805.12.2.3	Support fittings fill	370-16(b)(3)
E3805.12.2.4	Device or equipment fill	370-16(b)(4)
E3805.12.2.5	Equipment grounding conductor fill	370-16(b)(5)
E3805.12.3	Conduit bodies	370-16(c)

IRC Section	Section Title	NEC Section
E3806	INSTALLATION OF BOXES, CONDUIT BODIES AND FITTINGS	
E3806.1	Conductors entering boxes, conduit bodies or fittings	370-17
E3806.1.1	Insulated fittings	300-4(f)
E3806.2	Openings	370-17(a)
E3806.3	Metal boxes, conduit bodies and fittings	370-17(b)
E3806.4	Unused openings	370-18
E3806.5	In wall or ceiling	370-20
E3806.6	Plaster, gypsum board and plasterboard	370-21
E3806.7	Exposed surface extensions	370-22
E3806.8	Supports	370-23
E3806.8.1	Surface mounting	370-23(a)
E3806.8.2	Structural mounting	370-23(b)
E3806.8.2.1	Nails	370-23(b)(1)
E3806.8.2.2	Braces	370-23(b)(2)
E3806.8.3	Mounting in finished surfaces	370-23(c)
E3806.8.4	Raceway supported enclosures without devices or fixtures	370-23(e)
E3806.8.5	Raceway supported enclosures, with devices or fixtures	370-23(f)
E3806.8.6	Enclosures in concrete or masonry	370-23(f)
E3806.9	Covers and canopies	370-25
E3806.10	Metal covers and plates	370-25(a)
E3806.11	Exposed combustible finish	370-25(b)
E3807	CABINETS AND PANELBOARDS	
E3807.1	Damp or wet locations	373-2(a)
E3807.2	Position in wall	373-3
E3807.3	Unused openings	373-4
E3807.4	Conductors entering cabinets	300-3(f) and 373-5
E3807.5	Openings to be closed	373-5(a)
E3807.6	Cables	373-5(c)
E3808	GROUNDING	
E3808.1	Metal enclosures	250-86
E3808.2	Equipment fastened in place or connected by permanent wiring methods (fixed)	250-110
E3808.3	Specific equipment fastened in place or connected by permanent wiring methods	250-112
E3808.4	Performance of fault current path	250-2(d)
E3808.5	Earth as a grounding conductor	250-2(d)
E3808.6	Load-side neutral	250-142
E3808.7	Load-side equipment	250-142
E3808.8	Types of equipment grounding conductors	250-118
E3808.8.1	Flexible metal conduit	250-118(6)
E3808.8.2	Liquidtight flexible metal conduit	250-118(7)
E3808.8.3	Nonmetallic sheathed cable (Type NM)	336-30(b)
E3808.9	Equipment fastened in place or connected by permanent wiring methods	250-119
E3808.10	Methods of equipment grounding	250 Part G
E3808.11	Equipment grounding conductor installation	250-120
E3808.12	Equipment grounding conductor size	250-122
Table E3808.12	Equipment grounding conductor sizing	Table 250-122

IRC Section	Section Title	NEC Section
E3808	GROUNDING (Cont.)	
E3808.12.1	Multiple circuits	250-122(c)
E3808.13	Continuity and attachment of branch-circuit equipment grounding conductors to boxes	250-148
E3808.14	Connecting receptacle grounding terminal to box	250-146
E3808.15	Metal boxes	250-148(a)
E3808.16	Nonmetallic boxes	250-148(b))
E3808.17	Clean surfaces	250-12
E3808.18	Bonding other enclosures	250-96(a)
E3808.19	Size of equipment bonding jumper on load side of service	250-102(d)
E3808.20	Installation—equipment bonding jumper	250-102(e)

E3809	FLEXIBLE CORDS	
E3809.1	Where permitted	400-7 and 400-8
E3809.2	Loading and protection	400-5
Table E3809.2	Maximum ampere load and overcurrent-protection-device rating for flexible cords	240-4 and Table 400-5(A)
E3809.3	Splices	400-9
E3809.4	Attachment plugs	400-7(b)

CHAPTER 39 DEVICES AND LIGHTING FIXTURES

E3901	SWITCHES	
E3901.1	Rating and application of snap switches	380-14(a)
E3901.2	CO/ALR snap switches	380-14(c)
E3901.3	Indicating	380-7
E3901.4	Time switches and similar devices	380-5
E3901.5	Grounding of enclosures	380-12
E3901.6	Access	380-8
E3901.7	Wet locations	380-4
E3901.8	Grounded conductors	380-2(b)
E3901.9	Switch connections	380-2(a)
E3901.10	Box mounted	380-10(b)
E3901.11	Snap switch faceplates	380-9(a)
E3901.11.1	Faceplate grounding	380-9(b)

E3902	RECEPTACLES	
E3902.1	Rating and type	410-56(a)
E3902.1.1	Single receptacle	210-21(b)(1)
E3902.1.2	Two or more receptacles	210-21(b)(3)
Table E3902.1.2	Receptacle ratings for various size multioutlet circuits	210-21
E3902.2	Grounding type	210-7(a)
E3902.3	CO/ALR receptacles	410-56(b)
E3902.4	Faceplates	410-56(d)
E3902.5	Position of receptacle faces	410-56(e)
E3902.6	Receptacles mounted in boxes	410-56(f)(1) and (2)
E3902.7	Receptacles mounted on covers	410-56(f)(3)
E3902.8	Damp locations	410-57(a)
E3902.9	Wet locations	410-57(b)
E3902.10	Bathtub and shower space	410-57(c)

IRC Section	Section Title	NEC Section
E3902	RECEPTACLES (cont.)	
E3902.11	Flush mounting with faceplate	410-57(e)
E3902.12	Outdoor installation	410-57(f)
E3903	FIXTURES	
E3903.1	Energized parts	410-3
E3903.2	Fixtures near combustible material	410-5
E3903.3	Exposed conductive parts	410-18(a)
E3903.4	Screw-shell type	410-47
E3903.5	Recessed incandescent fixtures	410-65(c)
E3903.6	Thermal protection	410-73(e)
E3903.7	High-intensity discharge fixtures	410-73(f)
E3903.8	Wet or damp locations	410-4(a)
E3903.9	Lampholders in wet or damp locations	410-49
E3903.10	Pendants	410-4(d)
E3903.11	Fixtures in clothes closets	410-8(a)
Figure E3903.11	Closet storage space	Figure 410-8
E3903.12	Fixture wiring—general	410-22
E3903.12.1	Polarization of fixtures	410-23
E3903.12.2	Fixtures as raceways	410-31
E3904	FIXTURE INSTALLATION	
E3904.1	Outlet box covers	410-12
E3904.2	Combustible material at outlet boxes	410-13
E3904.3	Access	410-16(b)
E3904.4	Supports	410-15(a)
E3904.5	Means of support	410-16(a)
E3904.6	Exposed ballasts	410-76(a)
E3904.7	Combustible low-density cellulose fiberboard	410-76(b)
E3904.8	Recessed fixture clearance	410-66(a)
E3904.9	Recessed fixture installation	410-66(b)
E3905	TRACK LIGHTING	
E3905.1	Fastening	410-104
E3905.2	Grounding	410-105(b)

CHAPTER 40 APPLIANCE INSTALLATION

E4001	GENERAL	
E4001.1	Scope	422-1 and 424-1
E4001.2	Installation	110-3(b) and 422-17
E4001.3	Flexible cords	422-16
Table E4001.3	Flexible cord length	422-16(b)(1) and (2)
E4001.4	Overcurrent protection	422-11
E4001.4.1	Single motor-operated appliance	422-11(e)
E4001.5	Disconnecting means	422-30 and 424-19
Table E4001.5	Disconnecting means	422-21, 422-25, 422-27, 424-19, and 440-14
E4001.6	Ceiling fans	422-18

IRC Section	Section Title	NEC Section
E4001	GENERAL (Cont.)	
E4001.7	Snow-melting and deicing equipment protection	210-8(a)(3) Exception and 426-28
CHAPTER 41	SWIMMING POOLS	
E4101	GENERAL	
E4101.1	Scope	680-1
E4101.2	Definitions	680-4
E4102	WIRING METHODS FOR POOLS, SPAS, HOT TUBS AND HYDROMASSAGE BATHTUBS	
E4102.1	General	608-7, 680-20(b), 680-20(c), 680-25(b), 680-25(c), 680-25(d), 680-40 and 680-41
E4102.2	Flexible cords	680-6(b)(3), 680-7, 680-40 Exception No. 2, 680-41 Exception, 680-25(b)(3)
E4103	EQUIPMENT LOCATION AND CLEARANCES	
E4103.1	Receptacle outlets	680-6(a)
E4103.1.1	Location	680-6(a)(1)
E4103.1.2	Where required	680-6(a)(2)
E4103.1.3	GFCI Protection	680-6(a)(3)
E4103.1.4	Indoor Locations	680-41(a)(1)
E4103.1.5	Indoor GFCI Protection	680-41(a)(2), 680-70
E4103.2	Switching devices	680-6(c), 680-41(c), 680-71
E4103.3	Disconnecting means	680-12
E4103.4	Lighting fixtures and ceiling fans	680-6(b)
E4103.4.1	Outdoor Location	680-6(b)(1)
E4103.4.2	Indoor location	680-6(b)(3)
E4103.4.3	Existing lighting outlets and fixtures	680-6(b)(2)
E4103.4.4	Indoor spas and hot tubs	680-41(b)
E4103.4.5	GFCI Protection	680-6(b)(4)
E4103.5	Overhead conductor clearances	680-8
Table E4103.5	Overhead conductor clearances	Table 680-8
Figure E4103.5	Overhead conductor clearances	Figure 680-8
E4103.6	Underground Wiring	680-10
Table E4103.6	Minimum burial depths	680-10

IRC Section	Section Title	NEC Section
E4104	BONDING	
E4104.1	Bonded Parts	Sections 680-22(a), 680-40(b) and 680-41(d)(4)
E4104.2	Parts not required to be bonded	680-22(a) Exception No. 2, 680-22(a) Exception No. 4, 680-40 Exception No.1 and 680-41(d)(4) Exception
E4104.3	Methods of bonding	680-22(b), 680-40 Exception 3 and 680-41(e)

E4105	GROUNDING	
E4105.1	Equipment to be grounded	680-24
E4105.2	Light Fixtures	680-25(b)(1), 680-25(b)(2), 680-25(b)(3)
E4105.3	Nonmetallic conduit	680-20(b)(1)
E4105.4	Flexible cords	680-25(b)(3)
E4105.5	Motors	680-25(c)
E4105.6	Panelboards	680-25(d)
E4105.7	Cord-connected equipment	680-25(e)
E4105.8	Other equipment	680-25(f)

E4106	EQUIPMENT INSTALLATION	
E4106.1	Transformers	680-5(a)
E4106.2	Ground-fault circuit-interrupters	680-5(b)
E4106.3	Wiring on load side of ground-fault circuit-interrupters and transformers	680-5(c)
E4106.4	Underwater lighting fixtures	680-20(a)(1)
E4106.4.1	Maximum voltage	680-20(a)(2)
E4106.4.2	Fixture location	680(a)(3)
E4106.5	Wet-niche fixtures	680-20(b)(1), 680-20(b)(3)
E4106.6	Dry-niche fixtures	680-20(c)
E4106.7	No-niche fixtures	680-20(d)
E4106.8	Junction boxes and enclosures for transformers or ground-fault circuit interrupters	680-21
E4106.8.1	Junction boxes	680-21(a)
E4106.8.2	Other enclosures	680-21(b)
E4106.8.3	Protection of junction boxes and enclosures	680-21(c)
E4106.8.4	Grounding terminals	680-21(d)
E4106.8.5	Strain relief	680-21(e)
E4106.9	Underwater audio equipment	680-23
E4106.9.1	Speakers	680-23(a)
E4106.9.2	Wiring methods	680-23(b)
E4106.9.3	Forming shell and metal screen	680-23(c)
E4106.10	Electrically operated pool covers	680-26
E4106.11	Electric pool water heaters	680-9
E4106.12	Pool area heating	680-27

IRC Section	Section Title	NEC Section
E4106	EQUIPMENT INSTALLATION (Cont.)	
E4106.12.1	Unit heaters	680-27(a)
E4106.12.2	Permanently wired radiant heaters	680-27(b)
E4106.12.3	Radiant heating cables prohibited	680-27(c)
E4106.13	Double insulated pool pumps	680-28
E4107	STORABLE SWIMMING POOLS	
E4107.1	Pumps	680-30
E4107.2	Ground-fault circuit-interrupters required	680-31
E4107.3	Lighting fixtures	680-32
E4107.3.1	15 volts or less	680-32(a)
E4107.3.2	Not over 150 volts	680-32(b)
E4108	SPAS AND HOT TUBS	
E4108.1	Ground-fault circuit-interrupters	680-42
E4108.2	Electric water heaters	680-41(h)
E4108.3	Underwater audio equipment	680-41(i)
E4109	HYDROMASSAGE BATHTUBS	
E4109.1	Ground-fault circuit-interrupters	680-70
E4109.2	Other electric equipment	680-71
E4109.3	Accessibility	680-72
E4109.4	Bonding	680-73
CHAPTER 42	<u>CLASS 2 REMOTE CONTROL, SIGNALING, AND POWER-LIMITED CIRCUITS</u>	
E4201	GENERAL	
E4201.1	Scope	725-1
E4201.2	Definitions	Article 100 and Section 725-2
E4202	POWER SOURCES	
E4202.1	Power Sources for Class 2 circuits	725-41(a)
E4202.2	Interconnection of power sources	725-41(b)
E4203	WIRING METHODS	
E4203.1	Wiring methods on supply side of Class 2 power source	725-51
E4203.2	Wiring methods and materials on load side of the Class 2 power source	725-52, 725-61, 725-71
E4203.2.1	Type CL2P cables	725-71(a)
E4203.2.2	Type CL2 Cables	725-71(c)
E4203.2.3	Type CL2X Cables	725-61(e), Exception 4 and 725-71(d)
E4203.2.4	Marking	725-71(h)

IRC Section	Section Title	NEC Section
E4204	INSTALLATION REQUIREMENTS	
E4204.1	Separation from other conductors	725-54(a)(1)
E4204.2	Other applications	725-54(a)(3)
E4204.3	Class 2 circuits with communication circuits	725-54(b)(4)
E4204.4	Class 2 Cables with other circuit cables	725-54(b)(5)
E4204.5	Installation of conductors and cables	725-5, 725-7, 725-54(d)