

2006 INTERNATIONAL ENERGY
CONSERVATION CODE ERRATA
8TH PRINTING (Updated APRIL 22, 2011)

2006 IECC
CHAPTER 5
COMMERCIAL ENERGY EFFICIENCY

503.2.7.1.3 High-pressure duct systems. Ducts designed to operate at static pressures in excess of 3 inches w.g. (746 Pa) shall be insulated and sealed in accordance with Section 503.2.7. In addition, ducts and plenums shall be leak-tested in accordance with the SMACNA *HVAC Air Duct Leakage Test Manual* with the rate of air leakage (CL) less than or equal to 6.0 as determined in accordance with Equation 5-2.

$$\text{CL} = F \times P^{0.65} \quad \text{CL} = F / P^{0.65} \quad \text{(Equation 5-2)}$$

(No change to remainder of section)