

**CHAPTER 15  
ROOF ASSEMBLIES AND ROOFTOP STRUCTURES**

**TABLE 1507.4.3(1)  
METAL ROOF COVERING  
(No change to table)**

a. For Group U buildings, the minimum coating thickness for ASTM A 653 galvanized steel roofing shall be G-60. (*posted 1-31-07*)