

2006 International Fire Code Errata

FIRST PRINTING (Updated July 1, 2006)

CHAPTER 35 FLAMMABLE GASES

Insert Section 3503.1.6 to read as follows:

3503.1.6 Liquefied flammable gases and flammable gases in solution. Containers of liquefied flammable gases and flammable gases in solution shall be positioned in the upright position or positioned so that the pressure relief valve is in direct contact with the vapor space of the container.

Exceptions:

1. Containers of flammable gases in solution with a capacity of 1.3 gallons (5 L) or less.
2. Containers of flammable liquefied gases, with a capacity not exceeding 1.3 gallons (5 L), designed to preclude the discharge of liquid from safety relief devices. (*posted 7-10-06*)