

# 2006 International Fire Code Errata

THIRD PRINTING (Updated June 27, 2007)

## CHAPTER 9 FIRE PROTECTION SYSTEMS

**907.2.7 Group M.** A manual fire alarm system shall be installed in Group M occupancies having an occupant load of 500 or more persons or more than 100 persons above or below the lowest level of exit discharge. The initiation of a signal from a manual fire alarm box shall initiate alarm notification appliances as required by Section 907.10.

### Exceptions:

1. A manual fire alarm system is not required in covered mall buildings complying with Section 402 of the *International Building Code*.
2. Manual fire alarm boxes are not required where the building is equipped throughout with an automatic sprinkler system and the alarm notification appliances will automatically activate upon sprinkler water flow. *(posted 6-27-07)*

# 2006 International Fire Code Errata

SECOND PRINTING (Updated JANUARY 23, 2006)

## CHAPTER 9 FIRE PROTECTION SYSTEMS

**914.4.1 Automatic sprinkler system.** An approved automatic sprinkler system shall be installed throughout the entire building.

**Exceptions:**

1. That area of a building adjacent to or above the atrium need not be sprinklered, provided that portion of the building is separated from the atrium portion by not less than a 2-hour fire resistance-rated fire barrier or horizontal assembly, or both. *(posted 1-23-07)*
2. Where the ceilings of the atrium are more than 55 feet (16 764 mm) above the floor, sprinkler protection at the ceiling of the atrium is not required.

# 2006 International Fire Code Errata

FIRST PRINTING (Updated July 1, 2006)
---------------------------------------

## CHAPTER 9 FIRE PROTECTION SYSTEMS

**904.2.1 Hood system suppression.** Each required commercial kitchen exhaust hood and duct system required by Section ~~640~~ 609 to have a Type I hood shall be protected with an approved automatic fire-extinguishing system installed in accordance with this code. (*posted 7-10-06*)

**909.9.2:** Equation 9-8 is deleted. (*posted 7-10-06*)

**Table 910.3 :** Revise the section references in column 1, rows 3 through 6 of the table as follows: ~~940.2.3~~ 910.2.2. (*posted 7-10-06*)