

2006 International Fire Code Errata

THIRD PRINTING (Updated June 27, 2007)
--

APPENDIX D FIRE APPARATUS ACCESS ROADS

D104.1 Buildings exceeding three stories or 30 feet in height. Buildings or facilities exceeding 30 feet (9144 mm) or three stories in height shall have at least ~~three~~ two means of fire apparatus access for each structure. (*posted 06-27-07*)

2006 International Fire Code Errata

FIRST PRINTING (Updated July 1, 2006)

APPENDIX D FIRE APPARATUS ACCESS ROADS

D107.1 One- or two-family dwelling residential developments. Developments of...(no change)

Exceptions:

1. Where there are more than 30 dwelling units on a single public or private fire apparatus access road and all dwelling units are equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, 903.3.1.2 or ~~903.3.1.3.3~~ 903.3.1.3 , access from two directions shall not be required.
2. (No Change) (posted 7-10-06)