

CHAPTER 10
MEANS OF EGRESS

1008.1.1 Size of doors. *(no change to main text)*

Exceptions:

(no change to exceptions 1 through 7).

8. Door openings required to be accessible within Type B units shall have a minimum clear width of 31.75 inches (806 mm).

1014.2.6 Travel distance. The travel distance between any point in a Group I-2 occupancy patient sleeping room and an exit access door in that room shall not ~~e~~ exceed 50 feet (15 240 mm).

1027.3 Exit discharge location. Exterior balconies, *stairways* and *ramps* shall be located at least 10 feet (3048 mm) from adjacent *lot lines* and from other buildings on the same lot unless the adjacent building *exterior walls* and openings are protected in accordance with Section ~~704~~ 705 based on *fire separation distance*.