

2009 International Building Code Errata

(Portions of text and tables not shown are unaffected by the errata)

SIXTH PRINTING (Updated October 3, 2012)
--

CHAPTER 27

ELECTRICAL

[F] 2702.2.13 Pyrophoric materials. Emergency power shall be provided for occupancies with silane gas in accordance with the *International Fire Code*.

Renumber remaining sections 2702.2.14 through 2702.2.20 to be 2702.2.13. through 2702.2.19.