

2009 International Existing Building Code Errata

THIRD PRINTING (Updated)

CHAPTER 14 CONSTRUCTION SAFEGUARDS

1405.1 Stairways required. Where an ~~existing building~~ a building has been constructed to a height of 50 feet (15 240 mm) or four stories, or where an existing building exceeding 50 feet (15 240mm) in building height is altered, at least one temporary lighted *stairway* shall be provided unless one or more of the permanent stairways ~~is available for egress~~ are erected as the construction progresses.

1405.2 Maintenance of means of egress. Required *means of egress* shall be maintained at all times during construction, demolition, remodeling or alterations, ~~repairs~~ and *additions* to any building.

Exception: *Approved temporary means of egress systems and facilities.*

1406.1 Where required. Buildings ~~required to have a standpipe system in accordance with this code shall be provided with not less than one standpipe for use during construction.~~ Such standpipes shall be installed where the progress of construction is not more than 40 feet (12 192 mm) in height above the lowest level of fire department access. Such standpipe shall be provided with fire department hose connections at accessible locations adjacent to ~~usable stairs.~~ Such standpipes shall be extended as construction progresses to within one floor of the highest point of construction having secured decking or flooring.

In buildings required to have standpipes by Section 905.3.1, not less than one standpipe shall be provided for use during construction. Such standpipes shall be installed when the progress of construction is not more than 40 feet (12 192 mm) in height above the lowest level of fire department vehicle access. Such standpipe shall be provided with fire department hose connections at accessible locations adjacent to usable stairs. Such standpipes shall be extended as construction progresses to within one floor of the highest point of construction having secured checking or flooring.