

2009 International Fire Code Errata

SECOND PRINTING (Posted April 6, 2010)
--

APPENDIX J EMERGENCY RESPONDER RADIO COVERAGE

J103.3.3 Testing and proof of compliance. The emergency responder radio coverage system shall be inspected and tested annually or whenever structural changes occur including additions or remodels that could materially change the original field performance tests. Testing shall consist of the following:

1. through 4. (No change)
5. At the conclusion of the testing a report verify compliance with Section ~~J103.3.4~~ J103.2.4 shall be submitted to the *fire code official*.