

2009 International Fuel Gas Code Errata

FIRST PRINTING (Updated September 21, 2010)

**CHAPTER 4
GAS PIPING INSTALLATIONS**

**TABLE 402.4(35)
POLYETHYLENE PLASTIC PIPE TUBING**

2009 International Fuel Gas Code Errata

FIRST PRINTING (Updated September 21, 2010)

CHAPTER 5 CHIMNEYS AND VENTS

FIGURE 503.5.4 TYPICAL TERMINATION LOCATIONS FOR CHIMNEYS AND SINGLE-WALL METAL PIPES SERVING RESIDENTIAL-TYPE AND LOW-HEAT ~~EQUIPMENT~~ APPLIANCES

TABLE 504.3.2
MAXIMUM VENT CONNECTOR LENGTH

CONNECTOR DIAMETER MAXIMUM (inches)	CONNECTOR MAXIMUM HORIZONTAL LENGTH (feet)
---	--

(Remainder of Table is unchanged)

504.3.20 Chimney and vent location. Tables 504.3(1), 504.3(2), 504.3(3), 504.3(4), and 504.3(5) shall be used only for chimneys and vents not exposed to the outdoors below the roof line. A Type B vent or listed chimney lining system passing through an unused masonry chimney flue shall not be considered to be exposed to the outdoors. A Type B vent shall not be considered to be exposed to the outdoors where it passes through an unventilated enclosure or chase insulated to a value of not less than R8.

Tables ~~504.3(6) and 504.3(7)~~ 504.3(6a), 504.3(6b), 504.3(7a) and 504.3(7b) shall be used for clay-tile-lined *exterior masonry chimneys*, provided that all of the following conditions are met:

(Remainder of text is unchanged)