

ERRATA – 2009 International Fuel Gas Code Study Companion

Page 32 Illustrations.

Revise the left illustration caption to read: Combustion air for horizontal ducts shall be a minimum of 1 square inch per 2,000 BTU/hr.

Revise the right illustration caption to read: Combustion air for vertical ducts shall be a minimum of 1 square inch per 4,000 BTU/hr.