

2009 International Mechanical Code Errata

1 ST , 2 ND , AND 3 RD PRINTING (Updated September 21, 2010)

CHAPTER 3 GENERAL REGULATIONS

[FG] 304.5 Hydrogen-generating and refueling operations. Ventilation shall be required in accordance with Section 304.5.1, 304.5.2 or 304.5.3 in public garages, private garages, repair garages, automotive ~~service stations~~ motor fuel-dispensing facilities and parking garages that contain hydrogen-generating appliances or refueling systems. For the purpose of this section, rooms or spaces that are not part of the living space of a *dwelling unit* and that communicate directly with a private garage through openings shall be considered to be part of the private garage.