

# 2009 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1<sup>st</sup> through 4<sup>th</sup> PRINTING (SEPTEMBER 14, 2009)

## CHAPTER 11 ENERGY EFFICIENCY

**TABLE N1102.1**  
**INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT<sup>a</sup>**

CLIMATE ZONE	FENESTRATION U-FACTOR	SKYLIGHT <sup>b</sup> U-FACTOR	GLAZED FENESTRATION SHGC	CEILING R-VALUE	WOOD FRAME WALL R-VALUE	MASS WALL R-VALUE	FLOOR R-VALUE	BASEMENT <sup>c</sup> WALL R-VALUE	SLAB R-VALUE AND DEPTH	CRAWL SPACE <sup>c</sup> WALL R-VALUE
5 and Marine 4	0.35	0.60	NR	38	20 or 13 + 5 <sup>h</sup>	13/17	<del>30<sup>i</sup></del> 30 <sup>d</sup>	10/13	10, 2 ft	10/13

# 2009 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1<sup>st</sup> and 2<sup>nd</sup> PRINTING (JULY 14, 2011)

## CHAPTER 11 ENERGY EFFICIENCY

**N1102.2.2 Ceilings without attic spaces.** Where .....requirements of Section ~~402.1.4~~ N1102.1 shall be limited.....

**N1102.4.5 Recessed lighting.** Recessed.....when tested at 1.57 ~~psi~~ psf (75 Pa) pressure differential.....