

2009 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st and 2nd PRINTING (SEPTEMBER 14, 2009)

CHAPTER 21 HYDRONIC PIPING

M2101.6 Drilling and notching. Wood-framed altered in accordance with the provisions of Section ~~R614~~ R613.

TABLE M2101.1 HYDRONIC PIPING MATERIALS

Note b. Standards as listed in Chapter ~~43~~ 44.

2009 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

| |
|---|
| 1 st PRINTING (SEPTEMBER 14, 2009) |
|---|

CHAPTER 21 HYDRONIC PIPING

M2103.2 Thermal barrier required. Radiant floor heating systems shall have a thermal barrier in accordance with Sections M2103.2.1 through M2103.2.4.

Exception: Insulation shall not be required in engineered systems where it can be demonstrated that the insulation will decrease the efficiency or have a negative effect on the installation.

M2103.2.4 Thermal barrier material marking. Insulation materials used in thermal barriers shall be installed so that the manufacturer's *R*-value mark is readily observable upon inspection.

Exception: ~~Insulation shall not be required in engineered systems where it can be demonstrated that the insulation will decrease the efficiency or have a negative effect on the installation.~~