

# 2012 International Building Code

## Errata

(Portions of text and tables not shown are unaffected by the errata)

<b>SECOND PRINTING (Updated May 23, 2012)</b>
---

### CHAPTER 12

#### INTERIOR ENVIRONMENT

**1203.1 General.** Buildings shall be provided with natural ventilation in accordance with Section 1203.4, or mechanical ventilation in accordance with the *International Mechanical Code*.

Where the air infiltration rate in a *dwelling unit* is less than 5 air changes per hour when tested with a blower door at a pressure 0.2 inch w.c. (50 Pa) in accordance with Section R402.4.1.2 of the *International Energy Conservation Code – Residential Provisions*, the *dwelling unit* shall be ventilated by mechanical means in accordance with Section 403 of the *International Mechanical Code*.