

2012 International Building Code Errata

(Portions of text and tables not shown are unaffected by the errata)

SECOND PRINTING (Updated May 23, 2012)

CHAPTER 27 ELECTRICAL

[F] 2702.2.13 Pyrophoric materials. ~~Emergency power shall be provided for occupancies with silane gas in accordance with the *International Fire Code*.~~

Renumber remaining sections 2702.2.14 through 2702.2.20 to be 2702.2.13. through 2702.2.19.