

2012 International Existing Building Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st and 2nd PRINTINGS (October 31, 2012)

CHAPTER 8 ALTERATIONS – LEVEL 2

801.1 Scope. Level 2 *alterations* as described in Section ~~504~~ 404 shall comply with the requirements of this chapter.

Exception: Buildings in which the reconfiguration is exclusively the result of compliance with the accessibility requirements of Section 705.2 shall be permitted to comply with Chapter 7.

1st PRINTING (March 5, 2012)

**CHAPTER 8
ALTERATIONS-LEVEL 2**

804.2.2 Groups A, B, E, F-1, H, I, M, R-1, R-2, R-4, S-1 and S-2. In buildings with occupancies in Groups A, B, E, F-1, H, I, M, R-1, R-2, R-4, S-1 and S-2, work areas that have exits or corridors shared by more than one tenant or that have exits or corridors serving an occupant load greater than 30 shall be provided with automatic sprinkler protection where all of the following conditions occur:

1. The *work area* is required to be provided with automatic sprinkler protection in accordance with the *International Building Code* as applicable to new construction; and
2. The *work area* exceeds 50 percent of the floor area; and

Exceptions:

- ~~1. Work areas in Group R occupancies three stories or less in height.~~
2. If the building does not have sufficient municipal water supply for design of a fire sprinkler system available to the floor without installation of a new fire pump, work areas shall be protected by an automatic smoke detection system throughout all occupiable spaces other than sleeping units or individual dwelling units that activates the occupant notification system in accordance with Sections 907.4, 907.5, and 907.6 of the *International Building Code*.