

2012 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (8-30-12)

CHAPTER 6 BUILDING SERVICES AND SYSTEMS

603.3.2.4 Installation. Tanks and piping systems shall be installed and separated from other uses in accordance with Section 915 and Chapter 13, both of the *International Mechanical Code*, as applicable.

Exception: Protected above-ground tanks complying with Section ~~5704.2.9.6~~ 5704.2.9.7 shall not be required to be separated from surrounding areas.