

2012 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 8-30-12)

CHAPTER 11 CONSTRUCTION REQUIREMENTS FOR EXISTING BUILDINGS

TABLE 1103.1 OCCUPANCY AND USE REQUIREMENTS^a

Page 182: In column one (SECTION) of the last row: ~~1104.4~~ 1104

1103.7 Fire alarm systems. An *approved* fire alarm system shall be installed in existing buildings and structures in accordance with Sections 1103.7.1 through 1103.7.7 and provide occupant notification in accordance with Section ~~907.6~~ 907.5 unless other requirements are provided by other sections of this code.

Exception: Occupancies with an existing, previously *approved* fire alarm system.

1103.7.5.1 Group R-1 hotel and motel manual fire alarm system. A manual fire alarm system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-1 hotels and motels more than three stories or with more than 20 *sleeping units*.

Exceptions: 1 & 2 (No change)

1103.7.5.1.1 Group R-1 hotel and motel automatic smoke detection system. An automatic smoke detection system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-1 hotels and motels throughout all interior *corridors* serving sleeping rooms not equipped with an *approved*, supervised sprinkler system installed in accordance with Section 903.

Exception: (No change)

1103.7.5.2 Group R-1 boarding and rooming houses manual fire alarm system. A manual fire alarm system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-1 boarding and rooming houses.

Exception: (No change)

1103.7.5.2.1 Group R-1 boarding and rooming houses automatic smoke detection system. An automatic smoke detection system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-1 boarding and rooming houses throughout all interior *corridors* serving *sleeping units* not equipped with an *approved*, supervised sprinkler system installed in accordance with Section 903.

Exception: (No change)

1103.7.6 Group R-2. A manual fire alarm system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-2 occupancies more than three stories in height or with more than 16 *dwelling* or *sleeping units*.

Exceptions: 1, 2 and 3 (No change)

1103.7.7 Group R-4. A manual fire alarm system that activates the occupant notification system in accordance with Section ~~907.6~~ 907.5 shall be installed in existing Group R-4 residential care/assisted living facilities in accordance with Section 907.2.10.1.

Exceptions: 1 & 2 (No change)

2012 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1104.1 General. *Means of egress* in existing buildings shall comply with the minimum egress requirements when specified in Table 1103.1 as further enumerated in Sections 1104.2 through ~~1104.23~~, 1104.24 and the building code that applied at the time of construction. Where the provisions of this chapter conflict with the building code that applied at the time of construction, the most restrictive provision shall apply. Existing buildings that were not required to comply with a building code at the time of construction shall comply with the minimum egress requirements when specified in Table 1103.1 as further enumerated in Sections 1104.2 through 1104.24.

1104.23 Stairway floor number signs. Existing *stairs* shall be marked in accordance with Section ~~4022.8~~ 1022.9.