

2012 International Fuel Gas Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 02-27-13)

CHAPTER 4 GAS PIPING INSTALLATIONS

402.4 Sizing tables and equations. Where Tables 402.4(1) through 402.4(35 ~~37~~) are used to size *pip*ing or tubing, the pipe length shall be determined in accordance with Section 402.4.1, 402.4.2 or 402.4.3.

[F] 412.6 Location. In addition to the fuel dispensing requirements of the *International Fire Code*, the point of transfer for dispensing operations shall be 25 feet (7620 mm) or more from: buildings having combustible exterior wall surfaces, buildings having noncombustible exterior wall surfaces that are not part of a 1-hour fire-resistance-rated assembly, ~~or~~ buildings having combustible overhangs, lot lines of property that could be built upon, public streets, ~~or~~ sidewalks and railroads; and at least 10 feet (3048 mm) from driveways and buildings having noncombustible exterior wall surfaces that are part of a fire-resistance-rated assembly having a rating of 1 hour or more.