

# 2012 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

---

1<sup>st</sup> through 8<sup>th</sup> PRINTING (POSTED September 5, 2018)

## CHAPTER 9 VENTS

**919.1 General.** Engineered vent systems shall comply with this section and the design, submittal, approval, inspection and testing requirements of Section ~~405.4~~ 316.

# 2012 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1<sup>st</sup> through 5<sup>th</sup> PRINTING (November 7, 2012)

## CHAPTER 9 VENTS

Table 906.1:

TABLE 906.1  
SIZE AND DEVELOPED LENGTH OF STACK VENTS AND VENT STACKS

DIAMETER OF SOIL OR WASTE STACK (inches)	TOTAL FIXTURE UNITS BEING VENTED (dfu)	MAXIMUM DEVELOPED LENGTH OF VENT (feet)* DIAMETER OF VENT (inches)										
		1 <sup>1</sup> / <sub>4</sub>	1 <sup>1</sup> / <sub>2</sub>	2	2 <sup>1</sup> / <sub>2</sub>	3	4	5	6	8	10	12
1 <sup>1</sup> / <sub>4</sub>	2	30										
1 <sup>1</sup> / <sub>2</sub>	8	50	150	—	—	—	—	—	—	—	—	—
1 <sup>1</sup> / <sub>2</sub>	10	30	100									
2	12		75	200								
2	20	30	50	150		—	—	—	—	—	—	—
2 <sup>1</sup> / <sub>2</sub>	42	26	30	100	300							
3	10		42	150	360	1,040						
3	21	—	32	110	270	810	—	—	—	—	—	—
3	53		27	94	230	680						
3	102		25	86	210	620						
4	43	—	35	85	250	980	—	—	—	—	—	—
4	140		27	65	200	750						

# 2012 International Plumbing Code Errata

1<sup>st</sup> and 2<sup>nd</sup> PRINTING (07-11-12)

## CHAPTER 9 VENTS

~~915.3~~ **2.2 Size and length.** The size of a combination waste and vent pipe shall be not less than that indicated in Table 915.3 2.2. The horizontal length of a combination waste and vent pipe shall be unlimited.

~~915.2.2~~ **3 Connection.** The combination waste and vent.... ~~The horizontal length of a combination waste and vent system shall be unlimited.~~

~~915.2.3~~ **4 Vent size.**

~~915.2.4~~ **2.5 Fixture branch or drain.**

Table 915.3

TABLE 915.3 **2.2**  
SIZE OF COMBINATION WASTE AND VENT PIPE

# 2012 International Plumbing Code Errata

---

1<sup>st</sup> PRINTING (11-28-2011)

## CHAPTER 9 VENTS

**915.2.3 Vent size.** The vent shall be sized for the total *drainage fixture unit* load in accordance with Section ~~916.2~~ 906.2.