

2012 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1 st through 5 th PRINTING (04-15-2014)

CHAPTER 34 GENERAL REQUIREMENTS

Section E3407.3 Ungrounded conductors. Insulation...

Exception: An insulated conductor....or three continuous white stripes shall be used only for the supply to the switch, not as a return conductor from the switch to the outlet.