

2012 International Green Construction Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: 06-06-12)

CHAPTER 7 WATER RESOURCE CONSERVATION, QUALITY AND EFFICIENCY

703.7.3 Metering. The metering of mechanical systems, system components, equipment and appliances shall be conducted in accordance with Section 705.2 1.

**TABLE 703.7.7
MINIMUM CYCLES OF CONCENTRATION
FOR DISCHARGE WATER**

MAKEUP WATER TOTAL HARDNESS (mg/L)^a	MAXIMUM MINIMUM CYCLES OF CONCENTRATION
---	---

703.9 Evaporative cooling. Evaporative cooling systems.....per ton-hour (~~4.2~~ 12 L per kWh)

704.1.4 Efficiency and listing. Water softeners....not less than 4000 grains of total hardness exchange per pound of salt (~~477~~ 571 g of total hardness exchange per kg of salt)..... All other water softeners shall have a rated salt efficiency of not less than 3,500 grains of total hardness exchange per pound of salt (~~477~~ 500 g of total hardness exchange per kg of salt), based on sodium chloride equivalency.

707.12.5 Inspection vermin and insect protection. Inlets and vents.....Section 707.8 7.

707.13 Operations and maintenance manuals. Operation and maintenance....in accordance with Sections 707.13.1 through 707.13.4.

708.5.1 Gray water systems for landscape irrigation. Gray water....with the exception of Sections 708.6 and 708.12.6-~~5~~ 4. Gray water....

708.14 Subsurface gray water irrigation systems. Gravity subsurface....Sections 708.6 and 708.12.6-~~5~~ 4.