

2015 International Building Code Errata

FIRST PRINTING (Updated September 11, 2014)

CHAPTER 27 ELECTRIC

[F] 2702.2.3 Emergency responder radio coverage systems. Standby power shall be provided for emergency responder radio coverage systems required in Section ~~915-916~~ and the *International Fire Code*. The standby power supply shall be capable of operating the emergency responder radio coverage system for a duration of not less than 24 hours.