

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)
--

CHAPTER 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

5704.2.7.5.8 Overfill prevention. An *approved* means or method in accordance with Section ~~5704.2.9.7.6~~ 5704.2.9.7.5 shall be provided to prevent the overfill of all Class I, II and IIIA liquid storage tanks. Storage tanks in refineries, bulk plants or terminals regulated by Section 5706.4 or 5706.7 shall have overfill protection in accordance with API 2350.

An *approved* means or method in accordance with Section ~~5704.2.9.7.6~~ 5704.2.9.7.5 shall be provided to prevent the overfilling of Class IIIB liquid storage tanks connected to fuel-burning equipment inside buildings.

Exception: Outside above-ground tanks with a capacity of 1,320 gallons (5000 L) or less.

5704.2.9.5.2 Fill pipe connections. Fill pipe connections for tanks storing Class I, II and IIIA liquids and Class IIIB liquids connected to fuel-burning equipment shall be in accordance with Section ~~5704.2.9.7.7~~ 5704.2.9.7.6.