

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FOURTH PRINTING (Updated September 15th, 2017)

CHAPTER 61 LIQUEFIED PETROLEUM GASES

6103.2.1.2 Construction and temporary heating. Portable LP-gas containers are allowed to be used in buildings or areas of buildings undergoing construction or for temporary heating as set forth in Sections [6.20.4](#), [6.20.5](#) and [6.20.8](#) ~~6.19.4, 6.19.5 and 6.19.8~~ of NFPA 58.

6107.2 Smoking and other sources of ignition. "No Smoking" signs complying with Section 310 shall be posted where required by the fire code official. Smoking within 25 feet (7620 mm) of a point of transfer, while filling operations are in progress at LP-gas containers or vehicles, shall be prohibited. Control of other sources of ignition shall comply with Chapter 3 of this code and Section [6.23](#) ~~6.22~~ of NFPA 58.

6109.11.2 Construction. The construction of such buildings and rooms shall comply with requirements for Group H occupancies in the International Building Code, Chapter 10 of NFPA 58 and both of the following:

1. Adequate vents shall be provided to the outside at both top and bottom, located not less than 5 feet (1524 mm) from building openings.
2. The entire area shall be classified for the purposes of ignition source control in accordance with Section [6.23](#) ~~6.22~~ of NFPA 58.

6104.4 Multiple LP-gas container installations. Multiple LP-gas container installations with a total water storage capacity of more than 180,000 gallons (681 300 L) [150,000- gallon (567 750 L) LP-gas capacity] shall be subdivided into groups containing not more than 180,000 gallons (681 300 L) in each group. Such groups shall be separated by a distance of not less than 50 feet (15 240 mm), unless the containers are protected in accordance with one of the following:

1. Mounded in an approved manner.
2. Protected with approved insulation on areas that are subject to impingement of ignited gas from pipelines or other leakage.
3. Protected by fire walls of approved construction.
4. Protected by an approved system for application of water as specified in [Table 6.4.1.2](#) ~~6.4.2~~ of NFPA 58.
5. Protected by other approved means.

Where one of these forms of protection is provided, the separation shall be not less than 25 feet (7620 mm) between LP-gas container groups.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FOURTH PRINTING (Updated October 3, 2016)
--

CHAPTER 61 LIQUEFIED PETROLEUM GASES

6108.1 General. Fire protection shall be provided for installations having LP-gas storage containers with a water capacity of more than 4,000 gallons (15 140 L), as required by ~~Section 6-25~~ 6.27 of NFPA 58.

2015 International Fire Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated October 30, 2014)

CHAPTER 61 LIQUEFIED PETROLEUM GASES

6104.3.2 Special hazards. LP-gas containers shall be located with respect to special hazards including, but not limited to, above-ground flammable or *combustible liquid* tanks, oxygen or gaseous hydrogen containers, flooding or electric power lines as specified in Section ~~6.4.5~~ 6.4.4 of NFPA 58.