

2015 International Fuel Gas Code Errata

(Portions of text and tables not shown are unaffected by the errata)

FIRST PRINTING (Updated XXXX XX, 2014)

[BF] 302.2 Penetrations of floor/ceiling assemblies and fire-resistance-rated assemblies. Penetrations of floor/ceiling assemblies and assemblies required to have a fire-resistance rating shall be protected in accordance with the *International Building Code*.