

2015 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1ST PRINTING (September 1, 2015)

CHAPTER 3 GENERAL REGULATIONS

**TABLE 305.4
PIPING SUPPORT SPACING^a**

PIPING MATERIAL	MAXIMUM HORIZONTAL SPACING (feet)	MAXIMUM VERTICAL SPACING (feet)
ABS pipe	4	10 ^c
Aluminum pipe and tubing	10	15
Brass pipe	10	10
Brass tubing, 1 ¹ / ₄ -inch diameter and smaller	6	10
Brass tubing, 1 ¹ / ₂ -inch diameter and larger	10	10
Cast-iron pipe ^b	5	15
Copper or copper-alloy pipe	12	10
Copper or copper-alloy tubing, 1 ¹ / ₄ -inch diameter and smaller	6	10
Copper or copper-alloy tubing, 1 ¹ / ₂ -inch diameter and larger	10	10
CPVC pipe or tubing, 1 inch and smaller	3	10 ^c
CPVC pipe or tubing, 1 ¹ / ₄ -inch and larger	4	10 ^c
Lead pipe	Continuous	4
PB pipe or tubing	2 ² / ₃ (32 inches)	4
PE-RT 1 inch and smaller	2 ² / ₃ (32 inches)	10 ^c
PE-RT 1 ¹ / ₄ inches and larger	4	10 ^c
PEX tubing	2 ² / ₃ (32 inches)	10 ^c
Polypropylene (PP) pipe or tubing, 1 inch or smaller	2 ² / ₃ (32 inches)	10 ^c
Polypropylene (PP) pipe or tubing, 1 ¹ / ₄ inches or larger	4	10 ^c
PVC pipe	4	10 ^c
Steel tubing	8	10
Steel pipe	12	15

2015 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1 ST PRINTING (October 30, 2014)

[BS] 301.16.1 ~~High-velocity wave action~~ **Coastal high hazard areas and coastal A zones**. In ~~flood hazard areas subject to high-velocity wave action~~ **coastal high hazard areas and coastal A zones**, mechanical systems and equipment shall not be mounted on or penetrate walls intended to break away under flood loads.