

# 2015 International Mechanical Code Errata

(Portions of text and tables not shown are unaffected by the errata)

<b>1<sup>ST</sup> PRINTING (October 30, 2014)</b>
---

**[F] 1109.1 Testing required.** The following emergency devices and systems shall be periodically tested in accordance with the manufacturer's instructions and as required by the code official:

1. Treatment and flaring systems.
2. Valves and appurtenances necessary to the operation of emergency refrigeration control boxes.
3. Fans and associated *equipment* intended to operate emergency **pure** ventilation systems.
4. Detection and alarm systems.