

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (June 24, 2014)

CHAPTER 2 DEFINITIONS

[A] APPROVED. Acceptable to the code official ~~or other authority having jurisdiction.~~

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1 st PRINTING (August 8, 2014)

CHAPTER 3 GENERAL REGULATIONS

307.6 Trench location. Trenches installed parallel to footing shall not extend below the 45-degree (0.79 rad) bearing plane of the footing or wall.

Renumber subsequent Section 307.7 to 307.6

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st through 3rd Printings (This Errata Posted: February 1, 2017)
--

CHAPTER 4 FIXTURES, FAUCETS, AND FIXTURE FITTINGS

406.2 Waste connection. The waste from....into a standpipe in accordance with Section ~~802.4~~ 802.3.3 or

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (Posted: December 8, 2015)

CHAPTER 4 FIXTURES, FAUCETS AND FIXTURE FITTINGS

[BE] 410.3 Provide high and low drinking fountains. Where drinking...

Exceptions:

1. A single drinking fountain.....
2. Where drinking fountains are primarily for children's use, the drinking fountains for people using wheelchairs shall be permitted to comply with the children's provisions in ICC A117.1 and drinking fountains for standing children shall be permitted to provide the spout at 30 inches (762 mm) minimum above the floor.

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st through 3rd Printings (This Errata Posted: January 1, 2017)

CHAPTER 6 WATER SUPPLY AND DISTRIBUTION

**TABLE 605.5
PIPE FITTINGS**

MATERIAL	STANDARD
Copper or copper alloy	ASME B16.15; ASME B16.18; ASME B16.22; ASME B 16.26; ASME B16.51; ASSE 1061; ASTM F 1476; ASTM F 1548

Portions of table and notes not shown are unchanged.

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st through 3rd Printings (This Errata Posted: February 1, 2017)

CHAPTER 7 SANITARY DRAINAGE

Table 709.1 DRAINAGE FIXTURE UNITS FOR FIXTURES AND GROUPS

Table is unchanged

Notes a. through f. unchanged

g. See Section 406.3 ~~2~~ for sizing.....

Note h. unchanged

**CHAPTER 7
SANITARY DRAINAGE**

711.1 Horizontal branch connections above or below vertical stack offsets. If a horizontal branch connects....Section 9067.

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (November 11, 2014)

CHAPTER 9 VENTS

Table 906.1:

TABLE 906.1
SIZE AND DEVELOPED LENGTH OF STACK VENTS AND VENT STACKS

DIAMETER OF SOIL OR WASTE STACK (inches)	TOTAL FIXTURE UNITS BEING VENTED (dfu)	MAXIMUM DEVELOPED LENGTH OF VENT (feet) ^a DIAMETER OF VENT (inches)										
		1 1/4	1 1/2	2	2 1/2	3	4	5	6	8	10	12
1 1/4	2	30										
1 1/2	8	50	150	—	—	—	—	—	—	—	—	—
1 1/2	10	30	100									
2	12		75	200								
2	20	30	50	150		—	—	—	—	—	—	—
2 1/2	42	26	30	100	300							
3	10		42	150	360	1,040						
3	21	—	32	110	270	810	—	—	—	—	—	—
3	53		27	94	230	680						
3	102		25	86	210	620						
4	43	—	35	85	250	980	—	—	—	—	—	—
4	140			27	65	200	750					

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st through 3rd Printings (Posted: January 17, 2017)

CHAPTER 10 TRAPS, INTERCEPTORS AND SEPARATORS

1003.3.4 Hydromechanical grease interceptors, fats, oils and greases disposal systems and automatic grease removal devices. Hydromechanical grease interceptors; fats, oils, and greases disposal systems and automatic grease removal devices shall be sized in accordance with ASME A112.14.3, ASME **A**112.14.4, ASME A112.14.6, CSA B481.3 or PDI G101. Hydromechanical grease interceptors; fats, oils, and greases disposal systems and automatic grease removal devices shall be designed and tested in accordance with ASME A112.14.3, ASME **A** 112.14.4, CSA B481.1, PDI G101 or PDI G102. Hydromechanical grease interceptors; fats, oils, and greases disposal systems and automatic grease removal devices shall be installed in accordance with the manufacturer's instructions. Where manufacturer's instructions are not provided, hydromechanical grease interceptors; fats, oils, and greases disposal systems and automatic grease removal devices shall be installed in compliance with ASME A112.14.3, ASME **A** 112.14.4, ASME A112.14.6, CSA B481.3 or PDI G101.

CHAPTER 10
TRAPS, INTERCEPTORS AND SEPARATORS

Section 1002.1 Fixture traps. Each plumbing fixture.....shall conform to Section ~~802.4~~ 802.3.3. A fixture shall not be double trapped.

(Exceptions remain unchanged)

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1st PRINTING (June 24, 2014)
--

CHAPTER 11 STORM DRAINAGE

1110.1 General. The roof of a structure shall be....the design, submittal, approval, inspection and testing requirements of Section 405.4 316.1.

2015 International Plumbing Code Errata

(Portions of text and tables not shown are unaffected by the errata)

2nd PRINTING (June 24, 2014)

CHAPTER 15 REFERENCE STANDARDS

ASME

~~A112.4-14.6-2010~~ A112.14.6-2010 FOG (Fats, Oils and Greases) Disposal Systems

ASTM

~~E2635--08~~ Standard Practice for Water Conservation in Buildings Through In-Situ Water Reclamation.....1304.3

UL

~~515—2011—~~ Electrical Resistance Heat Tracing for Commercial and Industrial Applications including—with revisions through November 30, 2011.....607.2.1.3.2