

# 2015 International Residential Code Errata

(Portions of text and tables not shown are unaffected by the errata)

1<sup>st</sup> PRINTING (October 30, 2014)

## CHAPTER 36 SERVICES

**E3603.1.1 Ungrounded service conductors.** For a service rated at 100 through 400 amperes, the service conductors supplying the entire load associated with a one-family dwelling, or the service conductors supplying the entire load associated with an individual dwelling unit in a two-family dwelling, shall have an ampacity of not less than 83 percent of the service rating.

**E3603.1.2 Ungrounded feeder conductors.** For a feeder rated at 100 through 400 amperes, the feeder conductors supplying the entire load associated with a one-family dwelling, or the feeder conductors supplying the entire load associated with an individual dwelling unit in a two-family dwelling, shall have an ampacity of not less than 83 percent of the feeder rating.

**E3603.1.3 Feeder size relative to service size.** A feeder for an individual dwelling unit shall not be required to have an ampacity greater than that specified in Sections E3603.1.1 and E3603.1.2.

**E3603.1.4 Grounded conductors.** The grounded conductor ampacity shall be not less than the maximum unbalance of the load and the size of the grounded conductor shall be not smaller than the required minimum grounding electrode conductor size specified in Table E3603.4. [310.15(B)(7)]