

**INTERNATIONAL PLUMBING CODE, CHAPTER 6
WATER SUPPLY AND DISTRIBUTION**

**SECTION 605
MATERIALS, JOINTS AND CONNECTIONS**

[Portions Omitted]

605.2 Lead content of water supply pipe and fittings. Pipe and pipe fittings, including valves and faucets, utilized in the water supply system shall have ~~a maximum of~~ not more than 8-percent lead content.

605.2.1 Lead content of drinking water pipe and fittings. Pipe, pipe fittings, joints, valves, faucets and fixture fittings utilized to supply water for drinking or cooking purposes shall comply with NSF 372 and shall have a weighted average lead content of 0.25 percent or less.

**CHAPTER 14
REFERENCED STANDARDS**

NSF

NSF International
789 Dixboro Road
Ann Arbor, MI 48105

Standard reference number	Title	Referenced in code section number
372-2010	Drinking Water System Components – Lead Content	605.2.1

