

**INTERNATIONAL CODE COUNCIL  
ELECTRICAL CODE  
ADMINISTRATIVE PROVISIONS  
HEARING RESULTS**

---

### **EL1-06/07**

**Committee Action:**                      **Approved as Submitted**

**Committee Reason:** Based upon the proponent's reason. Overcurrent devices cannot be repaired, they must be replaced.

**Assembly Action:**    **None**

---

### **EL2-06/07**

**Committee Action:**                      **Approved as Submitted**

**Committee Reason:** The added word recognizes that products and equipment are not only designed and constructed in accordance with the code but are also " installed."

**Assembly Action:**    **None**

---

### **EL3-06/07**

**Committee Action:**                      **Approved as Submitted**

**Committee Reason:** Coordinates terminology with the *International Building Code* and *International Fire Code* for smoke alarms.

**Assembly Action:**    **None**

---

### **EL4-06/07**

**Committee Action:**                      **Approved as Submitted**

**Committee Reason:** Appropriately updates to most current edition of referenced standards within the International Code Council Electrical Code Administrative Provisions.

**Assembly Action:**    **None**

---

