



The following publication, entitled *Required Changes to the 2012 International Residential Code to Comply with the A2L Refrigerant Related Code Provisions of the 2024 I-Codes*, is a copyrighted work owned by the International Code Council, Inc. ("ICC"). This document is provided for informational use only and should not be reproduced or distributed in any way without written permission from the ICC.

Jurisdictions that desire to adopt into legislation the provisions of this publication may do so through [incorporation by reference](#). For more information on this process, please contact ICC at 888-422-7233, ext. 3389 or at [schavez@iccsafe.org](mailto:schavez@iccsafe.org).



## Required Changes to the 2012 International Residential Code to Comply with the A2L Refrigerant Related Code Provisions of the 2024 I-Codes

Based on the  
2021 International Residential Code®  
2018 International Residential Code®  
2015 International Residential Code® and  
2012 International Residential Code®

Date of First Publication: June 14, 2024

First Printing: June 14, 2024

COPYRIGHT © 2024  
by  
INTERNATIONAL CODE COUNCIL, INC.

ALL RIGHTS RESERVED. This material is a copyrighted work owned by the International Code Council, Inc. (“ICC”). Without advance written permission from the ICC, no part of this material may be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example, and not limitation, photocopying or recording by or in an information storage retrieval system). For information on use rights and permissions, please contact: ICC Publications, 4051 Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICCSAFE (422-7233).

<https://www.iccsafe.org/about/periodicals-and-newsroom/icc-logo-license/>

Trademarks: “International Code Council,” the “International Code Council” logo, “ICC,” the “ICC” logo, “International Building Code,” “International Fire Code,” “International Mechanical Code” and other names and trademarks appearing in this publication are registered trademarks of the International Code Council, Inc., and/or its licensors (as applicable), and may not be used without permission.

PRINTED IN THE USA

# 2012 International Residential Code

## CHAPTER 14: HEATING AND COOLING EQUIPMENT AND APPLIANCES

### SECTION M1404—REFRIGERATION COOLING EQUIPMENT

**M1404.1 Compliance.** Refrigeration cooling *equipment* shall be *listed and labeled* in accordance with UL 484, UL 1995 or UL/CSA 60335-2-40.

### SECTION M1411—HEATING AND COOLING EQUIPMENT

**M1411.1 Approved refrigerants.** Refrigerants used in direct refrigerating systems shall conform to the applicable provisions of ANSI/ASHRAE 34.

**M1411.2 Refrigeration system listing.** Refrigeration systems using Group A2L refrigerants shall be listed and labeled to UL/CSA 60335-2-40. Refrigeration systems using Group A1 refrigerants shall be listed to UL/CSA 60335-2-40 or UL 1995. The equipment shall be installed in accordance with the listing.

**M1411.3 Refrigeration system installation.** Refrigeration systems shall be installed in accordance with the manufacturer's installation instructions. After installation, the manufacturer's installation instructions, owner's manuals, service manuals and any other product literature provided with the equipment shall be attached to the indoor unit or left with the homeowner.

**M1411.4 Field-installed accessories.** Field-installed accessories shall be installed in accordance with the accessory and equipment manufacturer's installation instructions. Accessories installed in the ductwork of Group A2L refrigeration systems shall not contain electric heating elements, open flames, or devices switching electrical loads greater than 2.5 kVA.

**M1411.5 Signs and identification.** Each refrigeration system using Group A2L refrigerant shall have the following information legibly and permanently indicated on a markable label provided by the equipment manufacturer.

1. Contact information of the responsible company that installed the refrigeration system.
2. The system refrigerant charge and the refrigerant number.

**M1411.6 Refrigerant charge.** Refrigeration systems shall have refrigerant charge in compliance with the equipment manufacturer's installation instructions and the requirements of the listing. Group A2L refrigerant charge for an individual refrigeration system shall not exceed 34.5 pounds (15.7 kg).

**M1411.7 Group A2L refrigerant piping testing.** The piping system containing Group A2L refrigerant shall be tested in accordance with the manufacturer's installation instructions and the requirements of the listing.

[Sections M1411.2 – 1411.6 become Sections 1411.8 – 1411.12.]

### SECTION M1412—ABSORPTION COOLING EQUIPMENT

**M1412.1 Listed equipment.** Absorption systems shall be installed in accordance with the manufacturer's instructions. Absorption *equipment* shall be *listed and labeled* in accordance with UL 1995 or UL/CSA/ANCE 60335-2-40.

## CHAPTER 20: BOILERS AND WATER HEATERS

### SECTION M2006—POOL HEATERS

**M2006.1 General.** Pool and spa heaters shall be installed in accordance with the manufacturer's installation instructions. Oil-fired pool heaters shall be *listed and labeled* in accordance with UL 726. Electric pool and spa heaters shall be *listed and labeled* in accordance with UL 1261. Pool and spa heat pump water heaters shall be *listed and labeled* in accordance with UL 1995 or UL/CSA/ANCE 60335-2-40.

## CHAPTER 44: REFERENCED STANDARDS

### ASHRAE

ASHRAE  
180 Technology Parkway  
Peachtree Corners, GA 30092

ASHRAE 34-2022 Designation and Safety Classification of Refrigerants

### UL

UL LLC  
333 Pfingsten Road  
Northbrook, IL 60062-2096

UL/CSA 60335-2-40—2022 Household and Similar Electrical Appliances—Safety—Part 2-40: Particular Requirements for Electrical Heat Pumps, Air-Conditioners and Dehumidifiers