



**cdpACCESS ONLINE ASSEMBLY MOTION VOTE
ERRATA
(Updated May 21, 2015)**

The cdpACCESS Online Assembly Motion Vote was posted at approximately 2:00 pm Central on May 14th and will be open until 11:59 pm Pacific on May 28th. Following the posting, errata has been identified and corrected in the system. The following is the errata that has been corrected as of the date noted below.

ICC Members who have cast a vote on the subject code change(s) prior to cdpACCESS being updated with the corrected information are encouraged to review their ballot to determine if the corrected information impacts their vote. Any vote can be changed at any time prior to the voting period closing.

**May 15, 2015
G42 - 15**

The following is a corrected Committee Reason statement for G42 -15, and replaces the previously posted statement:

The committee approved this proposal to provide clarification regarding the requirements for R-4 occupancies. While in general R-4 occupancies are to comply with R-3 standards, there are specific provisions which apply specifically to R-4 occupancies. The proposal also clarifies that only R-4 Condition 1 occupancies have the option of comply with the provisions of the IRC. This assures that the higher needs residents of an R-4 Condition 2 occupancy are covered by the standard of the IBC. Within the family of I-Codes, the R-4 occupancy will be provided with sprinkler protection regardless of the code it is developed under. The committee acknowledged that some state adoptions have removed sprinkler requirements in the IRC.

**May 21, 2015
E155 – 15**

This code change proposal should not be on the cdpACCESS Online Assembly Motion Vote. A review of the hearing video notes that an assembly motion was made but did not receive a second. As such, the motion failed. This code change proposal has been removed from the system.