

BCAC STUCTURAL WG GROUP B 2019 PROJECT LIST - OCTOBER 2-3, 2018 MTG - Copyright © 2018 International Code Council, Inc.

ITEM	SECTION	PROPOSED BY	TOPIC	3/13-14, 2018 NOTES	6/19-20, 2018 NOTES	Sept 11, 2018 NOTES	October 2-3, 2018 NOTES
IBC 15-1	1504.2.1.1 and 1504.2.1.2	Staff	Applicability of SBCCI SSTD 11-97	Is this in ICC 600? Look at C1568-13 as possible alternative Marc Nard/John Taecker to investigate	Still need to investigate alternative standards to wind tunnel testing. Two other ASTM standards are included under the SBCCI standard. ASTM C1569 and C1570.	No action	
IBC 23-1	2303.7	Staff	Clarification of lumber shrinkage	Move forward to WG	Check Section 2304.3.3 for requirements also.	No action	
IBC 15-2/IRC 9-1	Chapter 15 IBC and Chapter 9 IRC	Mike Fischer	Reference to manufacturer's approved installation instructions	Move forward to WG	"Approved" is the wrong word. The CO does not approve the manufacturer's instructions they are part of the listing	No action	
IRC 6-1	R602.6	Staff GG	Notching and boring clarifications	Move forward to WG	Code is not currently broken. Everyone understands the requirements. Possibly consider referencing a section...consider consistency with NDS provisions.	Jack Applegate indicated that the clarifications were needed, especially in the exception to Section 602.6.	
IRC 9-1	R905.17.4	Chuck Bajnai	Ice Shield clarifications	Move forward to WG	This is already contained in R905.2. Perhaps Section 905.17.4 should	No action	
IRC 3-1	R301.5	Chuck Bajnai	Guard clarifications	Coordinate with IBC requirements?	ASCE is considering proposals for testing requirements for guards. No BCAC proposal at this time.	No action	
IBC 17-1	1705.11.1	Gary Ehrlich	Special inspections structural wood windforce-resisting system	Move forward to WG	Move forward	No action	
IBC 15-3	1503.3	Amanda Hickman	Coping clarifications	Move forward to WG	Consider deleting the work "noncombustible" from the main paragraph rather than inserting the exception. Bruce Johnson and John Taecker want the BCAC to consider creating a Sub Work Group to research differences in the terms "roof systems" and "roof assembly."	Amanda Hickman and Mike Ennis agreed that an alternative proposal should be considered that strikes out the work noncombustible and revises the title to the section.	
IBC 15-4	1504.5	Amanda Hickman	Edge Securement clarifications	Move forward to WG	Move forward for work group discussion	No action	
IBC 15-5	1504.5.1	Amanda Hickman	Gutter Securement clarifications	Move forward to WG	Move forward for work group discussion	No action	
IBC 15-6 See also Group A item	Chapter 15 reorg	John Taecker Bruce Johnson	Clarify requirements	Move forward to WG	Also Chapter 9 of the IRC	No action	
IBC 23-2	2302, 2303, 2304	TWB/Gary Ehrlich	TWB issues	Move forward to WG	No BCAC proposal at this time.	No action	
IBC 15-7 (S22-16)	1504.9	NIST	Roof Aggregate	NA	New item since March meeting. NCSEA and NIST to collaborate, and then come to BCAC with proposal and reason for consideration. No BCAC proposal	No action	
IBC 19-1	1901.5	Staff	Re-bar specifications	NA	NA	New item. Jim Smith and Jack Applegate volunteered to move this item forward for further WG discussion.	

BCAC Structural WG

Chair: Gary Ehrlich

Marc

Jim Smith

Bruce Johnson

John Taecker